

# A STUDY OF SOME REACTOR SHIELDING PROBLEMS FOR SPACECRAFT APPLICATIONS

GPO PRICE \$ \_\_\_\_\_

CFSTI PRICE(S) \$ \_\_\_\_\_

Hard copy (HC) 3.00Microfiche (MF) .75

# 653 July 65

Work performed for  
National Aeronautics and Space Administration  
under the technical direction of  
George C. Marshall Space Flight Center  
Huntsville, Alabama

N66 31936

FACILITY FORM 602

(ACCESSION NUMBER)

(THRU)

114

(PAGES)

(CODE)

CR-76529

(CATEGORY)

**NUCLEAR AEROSPACE RESEARCH FACILITY****GENERAL DYNAMICS PORT WORTH**

567-37072-R

FZK-154

G|||||||D

## NUCLEAR AEROSPACE RESEARCH FACILITY

29 OCTOBER 1962

### A STUDY OF SOME REACTOR SHIELDING PROBLEMS FOR SPACECRAFT APPLICATIONS

E. E. JONES  
M. B. WELLS

Contract No. NAS8-1573

Work performed for  
National Aeronautics and Space Administration  
under the technical direction of  
George C. Marshall Space Flight Center  
Huntsville, Alabama

GENERAL DYNAMICS | FORT WORTH

## ABSTRACT

31936

Machine programs for computing the single-scattered neutron and gamma-ray fluxes from radiators of reactor-powered spacecraft are described and some calculated results for typical unshielded SNAP-8-powered spacecraft are presented. Calculations to investigate the effect of uniform expansion of a direct-beam shield on the transmitted neutron dose rate in the absence of a scattering atmosphere are reported. The results of some Monte Carlo calculations performed by GD/FW and the Technical Research Group of Syosset, N. Y., to investigate the effects of shield-splitting on neutron transmission through direct-beam shields in the absence of a scattering atmosphere are discussed.

#### ACKNOWLEDGMENTS

The authors wish to express their thanks to Mr. L. W. McCleary and Mr. B. R. Uzzell for their help in performing some of the calculations described in this report and to Mr. D. G. Collins for helpful discussions on the use of the Monte Carlo Code K97.

## TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT	3
ACKNOWLEDGMENTS	4
LIST OF FIGURES	7
LIST OF TABLES	9
I. INTRODUCTION	11
II. RADIATOR SCATTERING	15
2.1 Methods of Calculation	15
2.1.1 Neutrons: IBM Procedure S06	15
2.1.2 Gammas: IBM Procedure S14	29
2.2 Calculations	34
2.2.1 Geometry of Radiator Systems	37
2.2.2 Source Terms	39
2.3 Results	41
2.3.1 Flux and Dose	41
2.3.2 Relative Importance of Radiator Regions	49
2.4 Discussion of Results	50
2.4.1 Limitations	50
2.4.2 General Observations	52
III. DIRECT-BEAM SHIELDING	53
3.1 Expanded-Shield Studies	53
3.1.1 Geometry	53
3.1.2 Source	54
3.1.3 Method of Calculation	54
3.1.4 Results	54
3.2 Split Shield Considerations	65

TABLE OF CONTENTS (cont'd)

	<u>Page</u>
IV. CONCLUSIONS AND RECOMMENDATIONS	73
4.1 Radiator Scattering	73
4.2 Direct-Beam Shielding	74
APPENDIX A - FORTRAN STATEMENTS FOR S06	75
APPENDIX B - INPUT AND OUTPUT FOR S06 SAMPLE PROBLEM	87
APPENDIX C - FORTRAN STATEMENTS FOR S14	93
APPENDIX D - INPUT AND OUTPUT FOR S14 SAMPLE PROBLEM	103
APPENDIX E - MACHINE OPERATING INSTRUCTIONS FOR PROCEDURES S06 AND S14	111
REFERENCES	117
DISTRIBUTION	119

## LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1	Flat Configuration of 70-kwe SNAP-8 Interplanetary Spacecraft	12
2	Scattering Geometry	16
3	Format for Problem Data: Program S06	26
4	Format for Source Library: Program S06	27
5	Format for Cross-Section Library: Program S06	28
6	Format for Problem Data: Program S14	35
7	Format for Source Library: Program S14	36
8	Radiator Geometries Used in Calculations	38
9	Single-Scattered Neutron Spectra at Payload for Flat and Y Configurations	44
10	Direct-Beam Neutron Spectra at Payload for Flat and Y Configurations	45
11	Single-Scattered Gamma Spectra at Payload for Flat and Y Configurations	46
12	Direct-Beam Gamma Spectra at Payload for Flat and Y Configurations	47
13	Effect of Expanding 9-cm Polyethylene Shield: Plane Isotropic Source	55
14	Effect of Expanding 27-cm Polyethylene Shield: Plane Isotropic Source	56
15	Effect of Expanding 60-cm Polyethylene Shield: Plane Isotropic Source	57
16	Effect of Expanding 9-cm Polyethylene Shield: Plane Monodirectional Source	58
17	Effect of Expanding 27-cm Polyethylene Shield: Plane Monodirectional Source	59

LIST OF FIGURES (cont'd)

<u>Figure</u>		<u>Page</u>
18	Effect of Expanding 60-cm Polyethylene Shield: Plane Monodirectional Source	60
19	Transverse Neutron Leakage for Plane Isotropic Source	61
20	Transverse Neutron Leakage for Plane Monodirectional Source	62
21	Geometries for Configurations (1/2) and (1/3, 2/3)	69

NOTE:

The following pages were intentionally  
left blank: 2, 10, 72, 76, 88, 94,  
104, 110, 118 and 120.

## LIST OF TABLES

<u>Table</u>		<u>Page</u>
I	Neutron Source Terms for Unshielded SNAP-8 Reactor	42
II	Gamma Source Terms for Unshielded SNAP-8 Reactor	43
III	Total Neutron Flux Above 0.33 Mev	48
IV	Gamma Dose Rates	48
V	Neutron Fluxes for Various Shield Configurations	67




## I. INTRODUCTION

A number of presently conceived spacecraft designs utilize small nuclear reactors as sources of power. In most of these designs, the reactor powers a turboelectric generating system which supplies electricity to an ion propulsion system and to secondary equipment, such as transmitters and various scientific instruments. An example of this type of spacecraft is shown in Figure 1. Other spacecraft designs utilize a device for direct conversion of heat to electricity. In some vehicles, such as an orbiting satellite, the reactor will be used only as a source of electricity and will not furnish power to a propulsion system. In any event, relatively large radiating surfaces, such as those shown in Figure 1, will be required to dispose of waste heat.

Because of the reactor and the radiators, various parts of the spacecraft may be exposed to high scattered-neutron and -gamma fluxes. It is important, with respect to the design of such spacecraft, to predict the magnitudes of these fluxes so that a shield configuration can be designed which will reduce the neutron and gamma fluxes to allowable levels. It is of particular importance to know the magnitude of these fluxes at such places as the payload and propellant tank.

Both the neutron and gamma fluxes at any point will consist of two components: (1) the flux transmitted along a "line of sight"



**Figure 1. Flat Configuration of 70-kwe SNAP-8 Interplanetary Spacecraft**

from source to detector ( a component referred to as the "direct beam" and consisting of the uncollided flux plus that flux which is scattered within any material between the source and the detector) and (2) the flux scattered from the radiator surfaces and structural components. Although the total gamma flux would include a component due to neutron activation of the radiators and structural components, only those methods of calculating and shielding against the radiator-scattered and direct-beam fluxes are discussed in this report.

Particular effort has been directed toward setting up machine programs for calculating the radiator-scattered fluxes. The development and use of these programs are described and some results for typical spacecraft powered by unshielded SNAP-8 reactors are presented.

The problem of shielding against the direct-beam fluxes is considered from the standpoint of minimizing the required shielding by proper placement of the shield and by expanding or splitting the shield. In any case, the desired effect is to increase the transverse leakage of those neutrons and photons which scatter within the shield. Results of calculations performed at GD/FW to investigate the effects of shield expansion are presented and discussed. Calculations performed by the Technical Research Group at Syosset, New York to investigate the effects of shield placement and splitting are also discussed.

It should be pointed out that, thus far, this study has not been concerned with the actual design of specific shields, but has

been directed toward setting up methods of analysis and investigating some of the more important aspects of spacecraft reactor shielding. Recommendations are made for continuing this study in order to arrive at an integrated program for spacecraft reactor shield design and to evaluate presently conceived designs.

## II. RADIATOR SCATTERING

Equations for calculating the radiator-scattered neutron and gamma fluxes are developed in this section. The IBM programs for calculating these scattered fluxes are described in terms of calculational procedure, data input, and data output. Results of some calculations for typical spacecraft configurations are also given.


### 2.1 Methods of Calculation

#### 2.1.1 Neutrons: IBM Procedure S06

A FORTRAN program (S06) for calculating the neutron flux scattered from the radiators of reactor-powered spacecraft has been coded for the IBM-7090. This program is described below. The FORTRAN statements for S06 are given in Appendix A. Machine operating instructions are given in Appendix E. Input and output for a sample problem are given in Appendix B.

##### 2.1.1.1 Derivation of Equation for Scattered Neutron Flux

It is assumed that the reactor can be represented by a point source, with the origin of the coordinate system at the source. A simple example of the geometry involved is shown in the accompanying sketch. In all cases, it is assumed that the radiator, source, and detector lie in the same plane.



The radiator can be triangular or consist of rectangular and triangular sections. The base of each section must be parallel to the X axis. Each triangular section must be a right triangle with its area above its base, and the slopes of all hypotenuses must be equal and positive. This geometry was chosen because it lends itself to the analysis of systems such as the one illustrated in Figure 1 and those described in Reference 1.

To derive the expression for the scattered flux, consider the geometry illustrated in Figure 2. For the present, the source, detector, and radiator need not be in the same plane.




Figure 2. Scattering Geometry

Assume that the radiator is sufficiently thin so that the Z-dependence of the flux at any point in the radiator can be neglected. The flux in energy group L at the point (X,Y) is then given by  $S(L,X,Y)$ . It is important to note that in this formulation the source is represented by a point source, but that the source term,  $S(L,X,Y)$ , is calculated by considering the reactor core as a number of point sources distributed throughout the volume of the core.

Next, assume that all the neutrons at (X,Y) are traveling in the same direction. This assumption is consistent with the assumption of a point source and is feasible since the dimensions of the reactor core are small compared to R.

The number of group-L neutrons in the element of volume  $dXdYdZ$  at X,Y,Z which undergo single-scatterings through the angle  $\theta$  is given by

$$S(L,X,Y)\Sigma(L,\theta)dXdYdZ \text{ neutrons/sec-steradian},$$

where

$\Sigma(L,\theta)$  = differential scattering cross section of the radiator for group-L neutrons in units of  $\text{cm}^{-1}/\text{steradian}$ .

Neglecting energy loss due to scattering, the number of group-L neutrons passing through an element of area  $dS$ , which is located at the position of the detector and oriented perpendicular to D, and resulting from single-scattering in  $dXdYdZ$  is

$$S(L,X,Y)\Sigma(L,\theta)dXdYdZ e^{-\ell/\lambda(L)} \frac{dS}{D^2} \text{ neutrons/sec},$$

where

$\ell$  = slant distance in cm from the point  $(X, Y, Z)$  to the surface of the radiator, and

$\lambda$  = mean free path in cm of group L neutrons in the radiator.

Assuming the radiator to be sufficiently thin,  $\ell$  will be so small compared to  $\lambda(L)$  that the exponent may be neglected. The flux (or, more properly, the current) at  $dS$  will then be

$$\frac{S(L, X, Y)\Sigma(L, \theta)}{D^2} dXdYdZ \text{ neutrons/cm}^2\text{-sec.}$$

Since the detector is omnidirectional, the total single-scattered flux in energy group L is

$$\phi(L) = \iiint_{\text{volume}} \frac{S(L, X, Y)\Sigma(L, \theta)}{D^2} dXdYdZ \text{ neutrons/cm}^2\text{-sec.}$$

Since the integrand is independent of  $Z$ ,

$$\phi(L) = t \iint_{\text{area}} \frac{S(L, X, Y)\Sigma(L, \theta)}{D^2} dXdY \text{ neutrons/cm}^2\text{-sec.} \quad (1)$$

where  $t$  = thickness of radiator in cm.

It should be noted that Equation 1 has been derived without any assumptions with regard to the relative orientations of point source, radiator, and detector. As noted in Section 2.1.1, however, it will be assumed that all lie in the same plane and Equation 1 will be evaluated on that basis.

In formulating the expression for the scattered flux, the following assumptions were made:


1. Attenuation by the radiator can be neglected.
2. The neutron spectrum incident on the radiator can be represented by a number of discrete energy groups.
3. The scattered flux will consist only of single-scattered neutrons.
4. Energy loss due to scattering can be neglected.
5. The radiation leaking from the reactor can be treated as if emitted from a point source.

#### 2.1.1.2 IBM Calculational Procedure

Program S06 numerically evaluates Equation 1 for any number of energy groups (values of L) from 1 to 15. Since it is desirable to know which sections of the radiator contribute most of the scattered flux, the radiator may be broken up into as many as 20 sub-areas and the flux from each sub-area calculated.

The source terms  $S(L, X, Y)$  are supplied to the program as fluxes at points described by  $R$  and  $\alpha$  about the source (see Fig. 2). The integral in Equation 1 is evaluated by a double application of Simpson's rule for each sub-area. The procedures for evaluating the two terms in the integrand of Equation 1 for a given  $X$  and  $Y$  are described below.

Source Term  $S(L, X, Y)$ . The values of  $(R, \alpha)$  corresponding to  $(X, Y)$  are calculated in conventional fashion. The program then determines the input values of  $R$  and  $\alpha$  between which the point  $(R, \alpha)$  will lie (see sketch). By the use of linear interpolation with



$R_1$ ,  $R_2$ ,  $\alpha_1$ ,  
and  $\alpha_2$  are  
input values  
of  $R$  and  $\alpha$ .

respect to  $\alpha$ , the source terms  $S_1$  and  $S_2$  at the points (1) and (2) are determined. The source term at  $(R, \alpha)$  is then calculated by the expression

$$S(R, \alpha) = 1/2 (S_1 R_1^2 + S_2 R_2^2) / R^2. \quad (2)$$

Differential Scattering Cross Sections  $\Sigma(L, \theta)$ . The cosine of the scattering angle,  $\theta$ , is calculated by the equation

$$\cos \theta = \frac{(SEP)^2 - R^2 - D^2}{2RD}, \quad (3)$$

where  $R = (X^2 + Y^2)^{1/2}$  and  $(4)$

$$D = [R^2 + (SEP)^2 - 2(SEP)X]^{1/2}. \quad (5)$$

The differential scattering cross section in FORTRAN terminology is

$$\Sigma(L, \theta) = \sum_{NU=1}^{NUMAX} ATOM(NU) * SIG(L, \theta, NU), \quad (6)$$

where \* denotes multiplication and

ATOM(NU) = nuclear density of element NU in radiator in  
nuclei/cm<sup>3</sup> (input);

$$\text{SIG}(L, \theta, \text{NU}) = \frac{\text{SIGEL}(L, \text{NU})}{4\pi} \sum_{LL=1}^{\text{LLMAX}} (2LL-1)F(\text{NU}, L, LL)P(LL, \cos\theta); \quad (7)$$

SIGEL(L,NU) = elastic scattering cross section of element NU for  
group-L neutrons in barns (input);

F(NU,L,LL) = coefficients in Legendre expansion (input);

P(LL,cosθ) = Legendre polynomials (calculated by the program).

It should be noted that θ in Equation 3 refers to laboratory system coordinates, whereas most compilations of the coefficients F(NU,L,LL) are for scattering angles in the center-of-mass system. For most radiator materials, the mass number will be high enough to cause the error introduced in the results by use of the F(NU,L,LL)'s in the center-of-mass system in Equation 7 to negligible.

#### 2.1.1.3 Code Description of Radiator Geometry

The radiator configuration is described in XY coordinates, with the origin of the coordinate system always located at the source. The detector then always lies on the X-axis, a distance SEP from the origin. A sub-area is described in FORTRAN by seven quantities:

X0(K) and Y0(K)      Coordinates of the lower left corner of the sub-area K. No sub-area can have coordinates (0,0).

NPX(K) and NPY(K)      The number of points in the X and Y meshes for integration. NPX(K) and NPY(K) must all be odd integers.

KT(K)

A control number denoting whether sub-area K is rectangular or triangular.  
(=0 for rectangle, =1 for triangle).

DELX(K) and DELY(K) Intervals between points in the X and Y meshes for sub-area K.

For a triangular sub-area, NPY(K) and DELY(K) will be put in as zero and their values will then be computed by the program as follows:

$$NPY = 3 + (I-1)2,$$

where I = the index number of a point in the X-mesh which will assume values of 1 through NPX(K).

and

$$DELY = SLOPE(X-X0)/(NPY-1),$$

where SLOPE = the slope of the hypotenuse of the triangular sub-area.

#### 2.1.1.4 S06 Input Data

Definition of Input Quantities. The program input for a single problem will consist of (1) the problem data, (2) one library deck of source data, and (3) one to five libraries of cross-section data. A cross-section data library must be supplied for each element. Although up to 25 cross-section libraries may be loaded at the same time, a single problem can have a maximum of only five elements.

Only one source library can be read in at a time. If several problems are to be run in sequence, they must all use the same source library. All library data for a given sequence of problems must be read in before the problem decks are read in.

The quantities that comprise the problem data, the source-data library, and the cross-section data library are listed and defined below.

Problem Data

NA	Number of sub-areas (a positive integer).
NUMAX	Number of different nuclei which are treated as scatterers (a positive integer).
LLMAX1	The largest value of LLMAX which is to be used (a positive integer). LLMAX is defined under cross-section data.
NE	Number of energy groups (a positive integer). This must be the same in the problem data input, the source library, and all the cross-section libraries used in a particular problem.
SLOPE	Slope of hypotenuses of all triangular sub-areas in a particular problem (a decimal number).
SEP	Source-detector separation distance in cm (a decimal number).
YSLIB	Identification number of source library (a decimal number). Same digits appear in Columns 63 through 68 of source library cards.
THICK	Thickness of radiator in cm (a decimal number).
NPX(K)	Number of points in X-mesh for sub-area K (a positive integer: NA values).
NPY(K)	Number of points in Y-mesh for sub-area K (a positive integer: NA values).
KT(K)	Denotes rectangular (KT = 0) or triangular (KT = 1) sub-area (NA values).
XO(K)	X-coordinate of lower left corner of sub-area K in cm (a decimal number: NA values).
YO(K)	Y-coordinate of lower left corner of sub-area K in cm (a decimal number: NA values).

Problem Data (cont'd)

DELX(K)	Interval between points in X-mesh of sub-area K in cm (a decimal number: NA values).
DELY(K)	Interval between points in Y-mesh of sub-area K in cm (a decimal number: NA values).
ATOM(NU)	Nuclear density of element NU in nuclei/cm <sup>3</sup> (a decimal number with exponent: NUMAX values).
YLIB(NU)	Library identification number of cross-section data library for element NU (a decimal number: NUMAX values).

Source Data

NE	Defined under problem data.
MMAX	Number of values of R for which source points are defined (a positive integer).
NMAX	Number of values of $\alpha$ for which source points are defined (a positive integer).
R1(M)	Values of R in cm at which sources are defined (a decimal number: MMAX values in increasing order).
ALPHA1(N)	Values of $\alpha$ at which sources are defined; has units of degrees (a decimal number: NMAX values in increasing order).
S(L,M,N)	Source terms (flux) for energy group L, radius R1(M), and angle ALPHA1(N) (a decimal number with exponent: NE • MMAX • NMAX values).

Cross-Section Data

LLMAX	Number of terms in Legendre expansion of cross section (a positive integer).
NE	Defined in problem data.
SIGEL(L)	Total elastic scattering cross section for energy group L (a decimal number with exponent: NE values).

### Cross-Section Data (cont'd)

**F(L,LL)** Group L coefficients in Legendre expansion of cross section (a decimal number with exponent: NE • LLMAX values).

Limits on Quantity of Input Data. The quantity of input data is limited by the following maximum values:

<u>Quantity</u>	<u>Input</u>	<u>Maximum Value</u>
NA		20
NUMAX		5
LLMAX1		10
NE		15
MMAX		20
NMAX		20
LLMAX		10
NPX(K)		
Rectangular sub-area		99
Triangular sub-area		49
NPY(K)		99

Input Data Formats. Formats for preparing input data are shown in Figures 3 through 5. The first card of the problem deck contains no data. The first card of a source library has a 1 in Column 10. The first card of a cross-section library has a 2 in Column 10. With regard to entering the input on the data sheets, the following rules must be followed:

DIGITAL COMPUTER DATA SHEET

**CONVAIR GENERAL DYNAMICS CORPORATION**

DEPARTMENT 5

卷之三

卷之三

PROBLEMS

**Figure 3.** Format for Problem Data: Program SOK

## ROUTINE FOR RADIATOR-SCATTERED NEUTRONS.

## PROGRAM 506

PROGRAM 506															
ROUTINE FOR RADIATOR-SCATTERED NEUTRONS.															
TELETRONIC DYNAMICS CORPORATION															
1	NE	MMAX	NMAX												
2	R1(1)	R1(2)													
3	ALPHAI(1)	ALPHAI(2)													
4	S(1,1,1)	S(1,2,1)													
5	S(1,1,2)	S(1,2,2)													
6															
7	S(1,1,NMAX)	S(1,2,NMAX)													
8	S(2,1,1)	S(2,2,1)													
9															
10	2 3 4 5 6 7 8 9 10 11 12 13 14 15 16														
11															
12	S(2,1,NMAX)	S(2,2,NMAX)													
13															
14															
15															
16															
17															
18	S(NE,1,1)	S(NE,2,1)													
19															
20	S(NE,1,NMAX)	S(NE,2,NMAX)													
21															

NPC 15,019

L S06

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L

L&lt;/

NPC 15,020

**Figure 5.** Format for Cross-Section Library: Program S06

1. Integers must end in the last column of a data field, i.e., Column 10, 20, 30, 40, 50, or 60.
2. A Decimal Number can end anywhere in the data field.
3. A Decimal Number with Exponent must end in the last column of a data field ( $2.5 \times 10^6$  would be  $2.5 + 06$  or  $.25 + 07$ ).

#### 2.1.1.5 S06 Output Data

Output data from the program consists of the following:

1. Total flux at detector
2. Flux spectrum at detector
3. Flux from sub-areas
4. Fraction of total flux at detector from each sub-area
5. Flux spectrum at detector from each sub-area

With regard to the output data, the following should be noted:

1. If  $S(L, X, Y)$  is in units of  $n/cm^2\text{-sec-Mev}$ , then  $SIGEL(L)$  and  $F(L, LL)$  for each element are supplied for each energy  $E(L)$ ;  $\phi(L)$  is then the flux at the detector in units of  $n/cm^2\text{-sec-Mev}$  and output items 1, 3, and 4 have no meaning.
2. If  $S(L, X, Y)$  is in units of  $n/cm^2\text{-sec}$  in energy group  $L$ , then  $SIGEL(L)$  and  $F(L, LL)$  for each element consist of their average values over energy group  $L$ ;  $\phi(L)$  then has units of  $n/cm^2\text{-sec}$  and all output items have meaning.

#### 2.1.2 Gammas: IBM Procedure S14

A program, S14, has also been coded to calculate the radiator-scattered gamma flux. This program is described below. The FORTRAN statements are listed in Appendix C. Input and output for a sample problem are given in Appendix D. Machine operating instructions are given in Appendix E.

The geometry involved is the same as in the neutron program.

#### 2.1.2.1 Derivation of Equation for Scattered Gamma Flux

In formulating the expression for the scattered gamma flux, the following assumptions were made:

1. Attenuation in the radiator can be neglected.
2. The gamma spectrum incident on the radiator can be represented by a number of discrete energy groups.
3. The scattered flux will consist of only single-scattered gammas.
4. An average energy can be assigned to each energy group, and this energy can be used in calculating the cross section for Compton scattering.
5. The radiation leaking from the reactor can be treated as if emitted from a point source.

With these assumptions, the scattered flux  $\phi(L)$  in energy group L is given by

$$\phi(L) = t \iint_{\text{area}} \sum_{L'=1}^L \frac{S(L', X, Y)}{D^2} \sum (\theta, L' \rightarrow L) dX dY, \quad (8)$$

where  $\phi(L)$  = scattered flux in energy group L in photons/cm<sup>2</sup>-sec;

t = thickness of radiator in cm;

$S(L', X, Y)$  = flux in energy group L' incident on the radiator at the point (X, Y) in photons/cm<sup>2</sup>-sec;

D = distance from scattering point to detector in cm;

$\Sigma(\theta, L')$  = differential scattering cross section of radiator for group-L' photons in cm<sup>-1</sup>/steradian;

$F(\theta, L' \rightarrow L)$  = "probability" that a group-L' photon which scatters through angle  $\theta$  will end up in group-L. This will always be either zero or unity, depending on  $\theta$ , L', and L.

### 2.1.2.2 IBM Calculational Procedure

With the exception of  $\Sigma(L', \theta)$  and  $F(\theta, L' \rightarrow L)$ , which are discussed below, the quantities in Equation 8 are calculated in the same manner as in IBM Procedure S06.

Differential Scattering Cross Section. The cosine of the scattering angle,  $\theta$ , is calculated as in the neutron program (S06). The ratio of final to initial energy,  $P(L)$ , is then calculated by the equation

$$P(L) = 1 / [1 + \gamma_0(L)(1 - \cos\theta)], \quad (9)$$

where  $\gamma_0(L) = E_0(L)/0.51$ , and

$E_0(L) =$  average energy of group-L photons, in Mev.

The differential scattering cross section is then given by

$$\Sigma(L, \theta) = N_e \left( \frac{r_0^2}{2} \right) (P - P^2(1 - \cos^2\theta) + P^3), \quad (10)$$

where  $N_e$  = number of electrons per  $\text{cm}^3$  in radiator,

$r_0$  = classical radius of electron, in cm.

Equations 9 and 10 are discussed in Reference 2.

$F(\theta, L' \rightarrow L)$ . This quantity is not actually calculated. Instead, the final energy,  $E_1$ , is calculated by

$$E_1(L) = E_0(L) P(L).$$

$E_1$  is then successively compared with the lower-energy limits  $E(L)$  of the energy groups, beginning with  $L = 1$ , until the group in which  $E_1$  lies is found. The group-L flux scattered from the point in question is then assigned to that particular group.

### 2.1.2.3 S14 Input Data

Definition of Input Quantities. The program input for a single problem will consist of (1) the problem data and (2) one library of source data. The library data for a given sequence of problems must be read in before the problem decks are read in. Only one source library may be read in at a time. Therefore, if several problems are to be run in sequence, they must all use the same source library.

The input quantities comprising the problem and library data are listed and defined as follows:

#### Problem Data

NA	Number of sub-areas (a positive integer).
NE	Number of energies (a positive integer). This must be the same in the problem data and source library.
SLOPE	Slope of the hypotenuses of all triangular sub-areas in a particular problem (a decimal number).
SEP	Source-detector separation distance, in cm (a decimal number).
YSLIB	Identification number of source library (a decimal number). Same digits as in Columns 63 through 68 of source library cards.
THICK	Thickness of radiator, in cm (a decimal number).
XNEL	Number of electrons per $\text{cm}^3$ in radiator (a decimal number with exponent).
NPX(K)	Number of points in X-mesh for sub-area K (a positive integer: NA values).
NPY(K)	Number of points in Y-mesh for sub-area K (a positive integer: NA values).

Problem Data (cont'd)

KT(K)	Denotes rectangular ( $KT = 0$ ) or triangular ( $KT = 1$ ) sub-area (NA values).
XO(K)	X-coordinate of lower left corner of sub-area K, in cm (a decimal number: NA values).
YO(K)	Y-coordinate of lower left corner of sub-area K, in cm (a decimal number: NA values).
DELX(K)	Interval between points in X-mesh of sub-area K, in cm (a decimal number: NA values).
DELY(K)	Interval between points in Y-mesh of sub-area K, in cm (a decimal number: NA values).

Source Library

NE	Defined under problem data.
MMAX	Number of values of R for which source points are defined (a positive integer).
NMAX	Number of values of $\alpha$ for which source points are defined (a positive integer).
R1(M)	Values of R in cm at which sources are defined (a decimal number: MMAX values in increasing order).
ALPHA1(N)	Values of $\alpha$ at which sources are defined; has units of degrees (a decimal number: NMAX values in increasing order).
E0(L)	Average energy in Mev of group-L photons (a decimal number with exponent: NE values).
E(L)	Lower energy bound of group L (a decimal number with exponent: NE values). It is important to note that <u><math>E(L = NE)</math> must always be zero, and the highest energy group must be Group 1.</u>
S(L,M,N)	Source term (flux) for energy group L, radius R1(M), and angle ALPHA1(N) (a decimal number with exponent: NE • MMAX • NMAX values).

Limits on Quantity of Input Data. The quantity of input data is limited by the following maximum values:

<u>Quantity Input</u>	<u>Maximum Value</u>
NA	20
NE	15
NMAX	20
MMAX	20
NPX(K) Rectangular sub-area	99
Triangular sub-area	49
NPY(K)	99

Input Data Formats. Formats for preparing input data are shown in Figures 6 and 7. The first card of the problem deck contains no data. The first card of a source library has a 1 in Column 10. The rules for entering input on data sheets are outlined in Section 2.1.1.

#### 2.1.2.4 S14 Output Data

Output from the program consists of the following:

1. Total flux at detector.
2. Flux spectrum at detector.
3. Total flux and flux spectrum from each sub-area.
4. Fraction of total flux at the detector from each sub-area.

#### 2.2 Calculations

Calculations have been carried out by use of the programs described above to determine the neutron and gamma fluxes scattered

PROGRAM S14		NPC 15,021	
RADIATOR-SCATTERED GAMMAS			
JOB NO.	PROBLEM NO.	CURRENT YEAR	LAST DIGIT OF
12	12	87	8
CAR NO.		00012	00012
		0002	0002
		0003	0003
		0004	0004
THICK			
XSLT B			
SLOPE			
NA			
XNEL			
NPX(1)	NPX(2)		
NPY(1)	NPY(2)		
KT(1)	KT(2)		
XO(1)	XO(2)		
YO(1)	YO(2)		
DELX(1)	DELX(2)		
DELY(1)	DELY(2)		
THICK			
XSLT B			
SLOPE			
NA			
NPX(NA)			
NPY(NA)			
KT(NA)			
XO(NA)			
YO(NA)			
DELX(NA)			
DELY(NA)			

Figure 6. Format for Problem Data: Program S14

NPC 15,022

PROGRAM - S14

RADIATOR-SCATTERED GAMMAS

LAST DIGIT OF CURRENT YEAR  
CURENT YEAR  
DEC  
CARB  
NO  
NO  
LAST DIGIT OF

NE	MMAX	NMAX
R1(1)	R1(2)	...
ALPHA1(1)	ALPHA1(2)	...
E0(1)	E0(2)	...
E(1)	E(2)	...
S(1,1,1)	S(1,2,1)	...
S(1,1,2)	S(1,2,2)	...
...	...	...
S(1,1,NMAX)	S(1,2,NMAX)	...
S(2,1,1)	S(2,2,1)	...
...	...	...
S(2,1,NMAX)	S(2,2,NMAX)	...
...	...	...
S(NE,1,1)	S(NE,2,1)	...
...	...	...
S(NE,1,NMAX)	S(NE,2,NMAX)	...
...	...	...
R1(NMAX)	ALPHA1(NMAX)	...
E0(NE)	E0(NE)	...
0.0+0.0	0.0+0.0	...
S(1,MMAX,1)	S(1,MMAX,2)	...
S(MMAX,NMAX)	S(MMAX,NMAX)	...
S(NE,MMAX,1)	S(NE,MMAX,2)	...
S(MMAX,NMAX)	S(MMAX,NMAX)	...

Figure 7. Format for Source Library: Program S14


from the radiators of typical unshielded SNAP-8-powered spacecraft having rectangular- and triangular-shaped radiators. Results of these calculations are discussed in the subsections that follow.

### 2.2.1 Geometry of Radiator Systems

Two radiator configurations based on specifications given in Reference 1 were treated: the "flat" configuration shown on page 7 and the "Y" configuration shown on page 11. The flat configuration consists of two rectangular-shaped radiators lying opposite one another in the same plane, one on each side of the axis of the spacecraft. The Y configuration consists of three triangular-shaped radiators mounted radially about the spacecraft axis, each with the same axial position.


The geometries used in these calculations are shown in Figures 8a and 8b. Calculations were performed for a single radiator of each configuration, so that the total flux would then be twice the flux from a single radiator in the flat configuration and three times the flux from a single radiator in the Y configuration. The circled numbers in Figure 8 indicate the detector locations used in the calculations. Detector 1 coincides with the location of the scientific payload, Detector 2 with that of the ion-propulsion-system propellant tank.

For purposes of calculation, the radiators in both configurations were assumed to consist entirely of aluminum and to be 0.45-cm thick. (By the present method of calculation, the scattered flux is directly proportional to radiator thickness.)



(a) Flat Configuration

All dimensions in centimeters



(b) Y Configuration

**Figure 8. Radiator Geometries Used in Calculations**

### 2.2.2 Source Terms

#### 2.2.2.1 Method of Calculating

Both neutron and gamma source terms were obtained by use of the GD/FW shield penetration program, C-17 (Ref. 3). The reactor core was treated as a number of point sources. The output from this program consists of differential fluxes (particles/cm<sup>2</sup>-sec-Mev-power unit) and dose rates. However, the radiator-scattered gamma calculation (S14) requires that the source terms consist of fluxes (particles/cm<sup>2</sup>-sec-power unit) instead of differential fluxes. In order to use in the S14 program the gamma source data generated by the C-17 program, the following procedure was used:

1. The differential gamma spectrum at each radius and angle was normalized to the value at 0.25 Mev.
2. An average normalized spectrum was calculated from the normalized spectra obtained in Step 1. This was possible since the normalized spectra were all quite similar in shape.
3. The average normalized spectrum was then integrated over energy intervals to obtain relative group fluxes. The flux-weighted energy for each energy group was also calculated.
4. The group fluxes (photons/cm<sup>2</sup>-sec-watt) at each angle and radius were then obtained by multiplying the differential flux at 0.25 Mev for each angle and radius by the relative group fluxes calculated in Step 3.


The source terms required by the S06 program for the neutron calculations are the differential fluxes calculated by the C-17 shield penetration program. Since results obtained from the radiator-scattered neutron program (S06) were the scattered differential

fluxes at each detector, it was necessary to integrate these results over energy to obtain the total scattered fluxes.

The neutron and gamma source terms for an unshielded SNAP-8 reactor are given in Tables I and II.

#### 2.2.2.2 Reactor Geometry and Composition

The composition and geometry of the unshielded SNAP-8 reactor, as used for input to the shield penetration program, were obtained from References 4 and 5 and are indicated below. Dimensions are in centimeters.



The Roman numerals indicate region numbers. The composition of each region is as follows:

<u>Region</u>	<u>Material</u>	<u>Density (gm/cm<sup>3</sup>)</u>
I (core)	NaK	0.0705
	H	0.0898
	Zr	4.82
	U-235	0.596
	Hastelloy-N	0.082
II, III, IV	Fe	8.0
V	Be	1.84
VI, VII	Al	0.74

## 2.3 Results

### 2.3.1 Flux and Dose

For an unshielded SNAP-8 reactor, the single scattered neutron and gamma spectra at the payload (Detector 1 in Figure 8) are given in Figures 9 and 11. For purposes of comparison, the unshielded direct-beam neutron and gamma spectra at the same detector positions are shown in Figures 10 and 12. The direct-beam spectra were obtained from the source data in Tables I and II. The integrated neutron fluxes and gamma dose rates are given in Tables III and IV. It should be pointed out that the unshielded dose rates and fluxes reported are those from a single radiator multiplied by 2 in the flat configuration and by 3 in the Y configuration. A reactor power of 600 kw thermal was assumed. The neutron elastic scattering cross sections and coefficients for the Legendre expansions for aluminum were taken from Reference 6.


TABLE I

NEUTRON SOURCE TERMS FOR UNSHIELDED SNAP-8 REACTOR  
(neutrons/cm<sup>2</sup>-sec-Mev-Watt)

$\alpha$ (deg)	R (cm)	Energy (Mev)									
		.33	1.0	2.0	3.0	4.0	6.0	8.0	10.0	14.0	18.0
0	24	2.72(6)	1.64(6)	1.92(6)	6.11(5)	3.55(5)	1.06(5)	3.18(4)	8.20(3)	2.54(2)	8.57(0)
	180	2.18(4)	1.32(4)	1.34(3)	5.12(3)	3.04(3)	9.43(2)	3.69(2)	1.14(2)	2.41(0)	7.48(-2)
	305	7.24(3)	4.38(3)	2.77(3)	1.71(3)	1.01(3)	3.16(2)	1.27(2)	4.00(1)	8.15(-1)	2.51(-2)
	650	1.53(3)	9.30(2)	5.89(2)	3.63(2)	2.16(2)	6.76(1)	2.77(1)	8.86(0)	1.76(-1)	5.36(-3)
	7000	1.32(1)	8.01(0)	4.33(0)	3.13(0)	1.87(0)	5.83(-1)	2.37(-1)	7.64(-2)	1.51(-3)	4.62(-5)
30	24	8.97(6)	2.57(6)	1.33(6)	2.76(5)	1.19(5)	2.82(4)	6.28(3)	1.35(3)	5.82(1)	1.92(0)
	180	9.43(4)	2.62(4)	1.35(4)	2.81(3)	1.22(3)	2.87(2)	6.31(1)	1.35(1)	5.73(-1)	1.86(-2)
	305	3.27(4)	9.08(3)	4.68(3)	9.69(2)	4.19(2)	9.87(1)	2.17(1)	4.62(0)	1.94(-1)	6.27(-3)
	650	7.14(3)	1.98(3)	1.02(3)	2.11(2)	9.14(1)	2.15(1)	4.72(0)	1.00(0)	4.24(-2)	1.37(-3)
	7000	6.16(1)	1.71(1)	1.82(0)	1.99(0)	7.88(-1)	1.85(-1)	4.07(-2)	8.62(-3)	3.66(-4)	1.18(-5)
60	24	6.83(6)	1.93(6)	9.90(5)	1.90(5)	8.30(4)	1.98(4)	4.44(3)	9.67(2)	4.28(1)	1.44(0)
	180	1.11(5)	3.15(4)	1.62(4)	3.06(3)	1.34(3)	3.22(2)	7.26(1)	1.59(1)	7.06(-1)	2.39(-2)
	305	3.92(4)	1.14(4)	5.70(3)	1.09(3)	4.72(2)	1.14(2)	2.58(1)	5.66(0)	2.53(-1)	8.57(-3)
	650	8.65(3)	2.45(3)	1.26(3)	2.41(2)	1.06(2)	2.54(1)	5.73(0)	1.26(0)	5.64(-2)	1.91(-3)
	7000	7.46(1)	2.11(1)	1.09(1)	2.08(0)	9.14(-1)	2.19(-1)	4.94(-2)	1.09(-2)	4.83(-4)	1.65(-5)
90	24	7.53(6)	2.20(6)	1.14(6)	2.27(5)	9.87(4)	2.38(4)	5.41(3)	1.19(3)	5.31(1)	1.81(0)
	180	1.42(5)	4.11(4)	2.14(4)	4.31(3)	1.86(3)	4.46(2)	1.01(2)	2.23(1)	9.99(-1)	3.42(-2)
	305	4.92(4)	1.43(4)	7.41(3)	1.49(3)	6.44(2)	1.54(2)	3.50(1)	7.70(0)	3.45(-1)	1.18(-2)
	650	1.08(4)	3.12(3)	1.62(3)	3.26(2)	1.41(2)	3.37(1)	7.64(0)	1.68(0)	7.52(-2)	2.57(-3)
	7000	9.31(1)	2.69(1)	1.40(1)	2.81(0)	1.22(0)	2.91(-1)	6.59(-2)	1.45(-2)	6.48(-4)	2.25(-5)
120	24	6.83(6)	1.93(6)	9.90(5)	1.90(5)	8.30(4)	1.98(4)	4.44(3)	9.67(2)	4.28(1)	1.44(0)
	180	1.11(5)	3.15(4)	1.62(4)	3.06(3)	1.34(3)	3.22(2)	7.26(1)	1.59(1)	7.06(-1)	2.39(-2)
	305	3.92(4)	1.14(4)	5.70(3)	1.09(3)	4.72(2)	1.14(2)	2.58(1)	5.66(0)	2.53(-1)	8.57(-3)
	650	8.65(3)	2.45(3)	1.26(3)	2.41(2)	1.02(2)	2.54(1)	5.73(0)	1.26(0)	5.64(-2)	1.91(-3)
	7000	7.46(1)	2.11(1)	1.09(1)	2.08(0)	9.14(-1)	2.19(-1)	4.94(-2)	1.09(-2)	4.83(-4)	1.65(-5)

TABLE II  
GAMMA SOURCE TERMS FOR UNSHIELDED SNAP-8 REACTOR  
(photons/cm<sup>2</sup>-sec-watt)

α (deg)	R (cm)	Energy Range (Mev)												
		9-10	8-9	7-8	6-7	5-6	4-5	3-4	2-3	1.5-2.0	1.0-1.5	.75-1.0	.50-.75	.25-.50
0	24	1.79(3) 1.40(1)	1.92(4) 1.50(2)	4.67(4) 3.65(2)	8.12(4) 6.33(2)	1.62(5) 1.27(3)	4.51(5) 3.52(3)	1.40(6) 1.09(4)	1.39(6) 1.09(4)	2.28(6) 1.78(4)	1.81(6) 1.41(4)	3.10(6) 2.42(4)	7.53(6) 5.89(4)	1.09(7) 8.50(4)
	180	4.61(0) 9.81(-1)	4.95(1) 1.05(-1)	2.75(1) 1.86(1)	1.20(2) 1.45(1)	2.09(2) 3.83(-1)	4.18(2) 2.45(-1)	1.16(3) 2.47(2)	3.60(3) 7.66(0)	3.59(3) 7.65(2)	4.68(3) 1.25(1)	7.90(3) 1.25(0)	1.94(4) 1.41(3)	2.80(4) 5.98(3)
	305	8.45(-3)												
	650													
	7000													
30	24	4.37(2) 8.35(0)	4.69(3) 8.97(1)	8.29(3) 1.59(2)	1.14(4) 2.18(2)	1.98(4) 2.79(2)	3.96(4) 1.35(2)	1.10(5) 2.69(2)	3.41(5) 2.32(3)	3.40(5) 2.31(3)	5.55(5) 6.53(3)	7.55(5) 8.48(3)	1.84(6) 1.45(4)	2.65(6) 3.53(4)
	180	2.97(0) 6.60(-1)	3.19(1) 7.08(0)	5.64(1) 2.25(1)	7.75(1) 1.72(1)	1.19(1) 2.99(1)	5.99(1) 2.58(-1)	1.66(2) 5.17(-1)	5.15(2) 1.44(0)	5.15(2) 4.45(0)	8.40(2) 7.25(0)	6.68(2) 5.78(0)	1.15(3) 9.85(0)	2.17(4) 2.40(1)
	305													
	650													
	7000													
60	24	9.47(2) 1.47(1)	1.00(4) 5.53(2)	1.78(4) 2.80(2)	4.24(4) 3.85(2)	8.49(4) 1.34(3)	2.36(5) 1.34(3)	7.30(5) 7.15(4)	7.30(5) 7.15(4)	9.48(5) 1.15(4)	1.62(6) 1.88(4)	3.93(6) 2.55(4)	5.70(6) 6.20(4)	
	180	5.15(0) 1.13(0)	5.13(0) 1.21(1)	9.78(1) 2.15(1)	1.35(2) 2.15(1)	4.67(2) 5.13(1)	1.30(3) 1.03(2)	4.02(3) 2.85(2)	4.00(3) 2.83(2)	6.55(3) 8.80(2)	5.23(3) 1.44(3)	8.93(3) 1.15(3)	2.17(4) 4.75(3)	
	305													
	650													
	7000													
90	24	1.03(3) 1.78(1)	1.09(4) 1.91(2)	1.93(4) 3.38(2)	2.66(4) 4.65(2)	4.61(4) 8.08(2)	9.23(4) 1.62(3)	2.57(5) 4.49(3)	7.94(5) 1.39(4)	1.30(6) 1.27(4)	1.03(6) 1.80(4)	1.76(6) 2.27(4)	4.28(6) 7.48(4)	
	180	6.15(0) 1.35(0)	6.60(1) 1.45(1)	1.17(2) 2.56(1)	1.60(2) 3.52(1)	2.79(2) 6.11(1)	5.58(2) 1.22(2)	1.55(3) 3.40(2)	4.80(3) 1.05(3)	7.80(3) 1.05(3)	6.23(3) 1.07(4)	1.07(4) 2.33(3)	2.55(4) 3.08(4)	
	305													
	650													
	7000													
120	24	9.47(2) 1.47(1)	1.00(4) 5.53(1)	1.78(4) 2.80(2)	4.24(4) 3.85(2)	8.49(4) 1.34(3)	2.36(5) 1.34(3)	7.31(5) 7.15(4)	6.30(5) 4.02(3)	1.19(6) 1.15(4)	1.62(6) 1.88(4)	3.93(6) 2.55(4)	5.70(6) 6.20(4)	
	180	5.15(0) 1.13(0)	5.13(0) 1.21(1)	9.78(1) 2.15(1)	1.35(2) 2.15(1)	4.67(2) 5.13(1)	1.30(3) 1.03(2)	4.02(3) 2.85(2)	4.00(3) 2.83(2)	6.55(3) 8.80(2)	5.23(3) 1.44(3)	8.93(3) 1.15(3)	2.17(4) 4.75(3)	
	305													
	650													
	7000													



**Figure 9. Single-Scattered Neutron Spectra at Payload for Flat and Y Configurations**




Figure 10. Direct-Beam Neutron Spectra at Payload  
for Flat and Y Configurations





Figure 11. Single-Scattered Gamma Spectra at Payload  
for Flat and Y Configurations



**Figure 12. Direct-Beam Gamma Spectra at Payload for Flat and Y Configurations**

TABLE III

TOTAL NEUTRON FLUX ABOVE 0.33 MEV  
(neutrons/cm<sup>2</sup>-sec-600 kw)

	Flat Configuration	Y Configuration
At Payload		
Scattered	$1.2 \times 10^8$	$1.1 \times 10^8$
Direct Beam	$2.6 \times 10^9$	$8.9 \times 10^8$
At Propellant Tank		
Scattered	$1.5 \times 10^8$	$1.7 \times 10^8$
Direct Beam	$4.0 \times 10^9$	$1.1 \times 10^9$

TABLE IV

GAMMA DOSE RATES  
(r/hr-600 kw)

	Flat Configuration	Y Configuration
At Payload		
Scattered	$1.5 \times 10^2$	$4.3 \times 10^2$
Direct Beam	$1.3 \times 10^4$	$4.3 \times 10^3$
At Propellant Tank		
Scattered	$1.7 \times 10^2$	$5.4 \times 10^2$
Direct Beam	$2.0 \times 10^4$	$5.4 \times 10^3$

The scattered gamma dose rates were obtained by the following expression:

$$\text{DOSE} = \sum_i f_i \phi_i,$$


where  $\phi_i$  = group i gamma flux,

$f_i$  = flux-to-dose conversion factor, approximated from the curve on page 19 of Reference 7.

The direct-beam dose rates were obtained from the C-17 shield penetration program results.


### 2.3.2 Relative Importance of Radiator Regions

Of interest is the relative importance of various segments of the radiator with regard to scattering. With the flat configuration divided into three equal areas, as shown below, the percentage of total scattered neutron flux above 0.33 Mev contributed by each area is as follows: area 1, 70%; area 2, 20%; and area 3, 10%. The percentage of scattered gamma dose rate contributed by each area is: for area 1, 73%; for area 2, 19%; and for area 3, 8%.



g

Next, consider the source-detector scattering surface arrangement shown below, where area A = area B.



For an angular-independent source term that varies as  $1/r^2$ , it can be shown that the scattered fluxes contributed by areas A and B are equal. This is true because, for a given scattering "point" in area A, there will be a "point" in area B for which the scattering angle and geometric attenuation from source to detector will be equal to the scattering angle and total geometric attenuation, respectively, for area A.

## 2.4 Discussion of Results

### 2.4.1 Limitations

The most important limitations on the radiator scattering calculations are:

1. Neglect of attenuation in the radiator.
2. Consideration only of single scattering.
3. Uncertainties in the source terms, particularly the neutron source term.

The errors introduced by the first two limitations compensate each other to some degree. It is not certain that the effects of either are significant.

Attenuation is neglected because accounting for it would require either that the reactor be treated as a number of source points or that a detailed knowledge of the angular distribution of the radiation leaving the reactor surface be obtained and an integration performed over the surface of the reactor. The latter approach would be the better of the two but, at present, methods are not available which would give the necessary angular distribution of leakage radiation. It should be pointed out that, while the reactor is assumed to be a point source as far as the geometry involved in the scattering calculations is concerned, the source terms used in the scattering calculations were obtained by treating the reactor core as a number of point sources.

In using the shield penetration program (C17, Ref. 3) for calculating neutron fluxes from systems which consist of both hydrogenous and nonhydrogenous materials, one is faced with certain basic limitations inherent in the application of moments method data to neutron penetration calculations. The most important of these are:

1. Difficulty in choosing the proper reference material.
2. Uncertainties due to boundary effects.

This points out the importance of more sophisticated methods for determining neutron source terms.

A reasonable estimate of the error introduced by the assumptions and uncertainties discussed above cannot be made.

#### 2.4.2 General Observations

From Reference 1, page 5, the total allowed radiation doses in the payload area are  $10^{13}$  n/cm<sup>2</sup> and  $10^9$  ergs/gm(C) for neutrons and gammas, respectively. For a  $10^4$ -hour operating period, the maximum allowable neutron flux and gamma dose rate are then  $2.8 \times 10^5$  n/cm<sup>2</sup>-sec and  $10^3$  r/hr, respectively. By comparing these numbers with those in Tables III and IV, one can see that, in the particular spacecraft treated in these calculations, it will be necessary to shield against both scattered and direct-beam neutrons. The gamma shielding required will depend on the gamma attenuation offered by the neutron shielding.

Since the scattering cross section for aluminum decreases with increasing neutron energy and its differential elastic scattering becomes highly anisotropic with increasing neutron energy, it is the low-energy neutrons leaking from the reactor that contribute most of the scattered flux. One can see this by comparing the shapes of the scattered and direct-beam neutron spectra, bearing in mind that energy loss due to scattering is negligible. This is fortunate, since it is easier to shield against low-energy neutrons than against those of high energy.

Conclusions and recommendations with regard to radiator scattering are discussed in Section 4.1 of this report.


### III. DIRECT-BEAM SHIELDING

Shielding against direct-beam radiation has been studied from the standpoint of reducing the required shielding by either splitting or uniformly expanding the shield in order to increase the transverse leakage of radiation scattered within the shield. The effect of shield placement has also been considered. Results of Monte Carlo calculations performed at GD/FW to investigate shield expansion are presented, and the results of calculations performed by the Technical Research Group to study shield splitting are discussed. Thus far, the GD/FW study of direct-beam shielding has been confined to neutrons.

#### 3.1 Expanded-Shield Studies

##### 3.1.1 Geometry

The geometry for the expanded-shield calculations is shown below.



The shield was assumed to be a right circular cylinder of polyethylene, 12 inches in diameter, which was uniformly expanded until 40% and 80% void fractions were achieved. Initial shield thicknesses of 9, 27,

and 60 cm were considered. For each of these solid-shield thicknesses, the source-detector separation distance was assumed to be equal to the thickness of the shield when expanded to 80% void. The total mass of each shield was assumed to remain constant.

### 3.1.2 Source

The energy spectrum of the source was taken to be the same as that leaking from a typical nuclear rocket engine reactor. Although this spectrum differs considerably from that of the SNAP-8 reactor, the general conclusions drawn from this study should be applicable.


Two source angular distributions - isotropic and monodirectional - were treated.

### 3.1.3 Method of Calculation


IBM procedure K97, a Monte Carlo program, was used to make the calculations. A complete description of the calculational method is presented in Reference 8.

### 3.1.4 Results


Uncollided, scattered, and total dose rates per source neutron per second are presented in Figures 13 through 18 as a function of void percent for both source angular distributions and each initial shield thickness. The uncollided dose rates were calculated by conventional methods. The number of neutrons that leak from the side of the shield per source neutron as a function of void percent is shown in Figures 19 and 20 for a plane isotropic source and a plane monodirectional source, respectively.



**Figure 13. Effect of Expanding 9-cm Polyethylene Shield:  
Plane Isotropic Source**



**Figure 14. Effect of Expanding 27-cm Polyethylene Shield:  
Plane Isotropic Source**



**Figure 15. Effect of Expanding 60-cm Polyethylene Shield:  
Plane Isotropic Source**







Figure 16. Effect of Expanding 9-cm Polyethylene Shield:  
Plane Monodirectional Source




**Figure 17. Effect of Expanding 27-cm Polyethylene Shield:  
Plane Monodirectional Source**



**Figure 18. Effect of Expanding 60-cm Polyethylene Shield:  
Plane Monodirectional Source**



**Figure 19. Transverse Neutron Leakage for Plane Isotropic Source**



**Figure 20. Transverse Neutron Leakage for Plane Monodirectional Source**

Figures 13 through 15 indicate that the total dose rate from a plane isotropic source is reduced by expanding the shield. With an isotropic source the effectiveness of shield expansion is expected to be at a maximum when the source is located at the face of a hydrogenous material, since scattering is predominantly in the forward direction. If the source were located a large distance from the shield, the incident radiation would be more normal and the effect of expansion would be reduced.

The high magnitude of the uncollided dose rate relative to the total dose rate for the 60-cm case (Fig. 15) is felt to be caused by the source energy spectrum. For small thicknesses of polyethylene, the major contribution to the dose at the detector results from neutrons which originate at the source with energies of less than 5.0 Mev. A 40.0-cm thickness of polyethylene, however, removes most of those neutrons with energies below 5.0 Mev. Since the scattering cross section decreases as the energy increases, the uncollided dose rate becomes more important for polyethylene thicknesses greater than 40 cm. This latter effect would not be as noticeable for the SNAP-8 spectrum, since this spectrum is harder than that used in the calculation reported here.

Figures 16 and 17 indicate that, for shield thickness of 9 and 27 cm and for a monodirectional source, the effect of expanding the shield toward the detector is to increase the dose rate. This is because the effect of moving scattering points closer to the detector is greater than that of increasing the transverse leakage.

Figure 18 indicates that for a plain monodirectional source and a 60-cm shield thickness, the result of expanding the shield toward the detector is, first, to decrease and, then, to increase the scattered dose. This is probably due to the larger source-detector separation distance used in this case. With a 40% expansion, the fractional change in separation distance between scattering points closer to the source, where the scattering is highest, is less than that in the other cases which used shorter source-detector separation distances. The increase in transverse leakage due to a 40% expansion, therefore, compensates for the decrease in geometric attenuation, which results from moving scattering points closer to the source. With further expansion, the effect of moving the scattering points closer to the detector is greater than the increase in transverse leakage and the dose-rate increases. If the distance from shield to detector had been held constant and the shield expanded toward the source, the opposite effect would have been observed since the scattering points would be moving farther from the detector. This illustrates the importance of proper placement of the shield with respect to source and detector.

Figures 19 and 20 indicate that most of the increase in transverse leakage due to expansion is due to expansion of the first few mean free paths of the solid shield. This is especially true for the isotropic source, as can be noted by the fact that the data for the three shield thicknesses are quite close together.

Since those neutrons which leak from the side of the shield could reach the detector by scattering off radiators or other structure, it may be necessary to consider them in calculating the radiator-scattered dose rates for a composite shield configuration. The spectrum of neutrons leaking from the shield would be softer than the source spectrum, since neutrons from the shield would have undergone collisions in a moderating medium. The spectrum at the detector due to these neutrons would be even softer, as indicated by the discussion in Section 2.4.2.

The results just discussed indicate that it is possible to obtain significant reduction in neutron dose rate by expanding the direct-beam shield, but that the effect of expansion is dependent on several factors, the more important of which are angular distribution of source, initial (solid) shield thickness, and source-detector separation distance. The effect of expansion will also be dependent on other factors which were not specifically covered in this study. These would be shielding material, source energy spectrum, configurations of source and detector, ratio of source-detector separation distance to shield diameter, and shield placement. In actual design, one would consider the gamma dose rate and expansion in connection with splitting (i.e., breaking the shield into several sections and re-distributing these sections).

### 3.2 Split Shield Considerations

The results of a Monte Carlo study on the effect of splitting and placement of shadow shield configurations appropriate to manned

nuclear rocket and ion-propelled vehicles has been reported by Aronson et al. in Reference 9. In that study, the geometry of the source-shield-detector configuration was axially symmetric and consisted of the source, a disc; the shield, a set of cylinders placed end-to-end; and the detector, a cylindrical cavity. The study considered both hydrogenous and nonhydrogenous shields. On pages 21, 22, and 23 of Reference 9 are listed ten tentative conclusions which Aronson et al. had obtained from their Monte Carlo results. The first three of these conclusions are (1) the neutron flux transmitted through a nonhydrogenous shield can be reduced appreciably by splitting the shield into two or more segments, (2) the dose reduction factor increases as the ratio of the source-detector separation distance to the shield radius increases until the ratio is so large that the unscattered flux predominates in the dose, and (3) the dose reduction due to splitting the shield increases with the thickness of the shield, up to some limiting thickness.

These conclusions are based mainly on their Monte Carlo results for a carbon shield in which the shield thickness was four feet and the disc source was emitting neutrons with energies in the fission spectrum and in directions defined by a cosine distribution. The source-detector separation distance used in the carbon-shield problems of interest in this discussion was 75 feet and the shield radius was five feet. These problems were run for cases where (1) the shield was located midway between the source and detector,

(2) the shield was split into two equal segments with one segment located one-third the way from the source to the detector and the other segment two-thirds of the way, and (3) the shield split into four equal segments, with a segment located at  $1/5$ ,  $2/5$ ,  $3/5$ , and  $4/5$  of the distance between the source and detector. The configurations for these problems are denoted as  $(1/2)$ ,  $(1/3, 2/3)$ , and  $(1/5, 2/5, 3/5, 4/5)$ , respectively. The results for each configuration are shown in Table V.

TABLE V  
NEUTRON FLUXES FOR VARIOUS SHIELD CONFIGURATIONS

Configuration	Uncollided Flux (n/cm <sup>2</sup> -sec)	Total Flux (n/cm <sup>2</sup> -sec)
$(1/2)$	$2.5 \times 10^{-11}$	$2.4 \times 10^{-10}$
$(1/3, 2/3)$	$1.92 \times 10^{-11}$	$9.6 \times 10^{-11}$
$(1/5, 2/5, 3/5, 4/5)$	$2.4 \times 10^{-11}$	$7.9 \times 10^{-11}$

The results shown for Configuration  $(1/3, 2/3)$  are the average of the results given in Table 6 of Reference 9 for problems 62 and 62A. These results show that splitting the shield into two segments reduces the flux in the detector cavity by 60% and that splitting it into four segments reduces the flux by 67%.


The uncollided flux should be the same for all three configurations. A hand calculation performed later in this study to determine the direct-beam component gave  $2.88 \times 10^{-11}$  n/cm<sup>2</sup>-sec as the uncollided flux, so that the uncollided fluxes in Table V appear to be underestimates, especially that for Configuration  $(1/3, 2/3)$ .

An examination of the geometries shown in Figure 21 for Configurations (1/2) and (1/3, 2/3) reveals that none of the neutrons incident on the shield in Configuration (1/2) will enter the shield at an angle greater than 16 deg. Similarly, there will not be any neutrons entering the shield of Configuration (1/3, 2/3) at angles greater than 23 deg. It appears, then, that the results for the mono-directional source, as described in Section 3.1.4, can be used to examine these configurations. These results indicate that expansion of the shield toward the source reduces the flux at the detector, and that expansion of the shield toward the detector increases the detected flux. In expanding the shield toward the detector, it was noted that the effect of an increase in shield transverse leakage was less than the effect of moving the scattering centers closer to the detector.


Another thing to note about the two configurations illustrated in Figure 21 is that twice as many source neutrons will enter the shield in Configuration (1/3, 2/3) as will enter the shield in Configuration (1/2). It is not evident that the additional transverse leakage that might be expected in Configuration (1/3, 2/3) over that in Configuration (1/2) will be great enough to overcome the effect of adding more source particles into the shield system and the effect of moving the scattering points in the second section of Configuration (1/3, 2/3) toward the detector.

In order to settle some of the questions raised on the magnitude of each of the effects just discussed, problems using the geometries

Configuration (1/2)



Configuration (1/3, 2/3)

**Figure 21. Geometries for Configurations (1/2) and (1/3, 2/3)**


of Configurations (1/2) and (1/3, 2/3) were prepared and run on the General Electric Flexible Monte Carlo Code FMC-N (Ref. 10). The results of the FMC-N calculations gave  $3.52 \times 10^{-9}$  n/cm<sup>2</sup>-sec for Configuration (1/2) and  $5.59 \times 10^{-9}$  n/cm<sup>2</sup>-sec for Configuration (1/3, 2/3). It is to be noted that these fluxes are considerably higher than those given in Table V and that the flux in the detector cavity of Configuration (1/3, 2/3) is higher than that in the cavity of Configuration (1/2).

In addition to giving the total fluxes, the FMC-N code prints out the number current leaking out of the main geometry into outside regions. The flux estimator used in the FMC-N total flux calculations is based on the method of statistical estimation, whereas the current-leakage estimator is an analog estimator. These current-leakage results, normalized to one particle per second entering the shield, show that the leakage into Outside Regions III and IV of Configuration (1/2) is approximately the same as the leakage into Outside Regions III, IV, and V of Configuration (1/3, 2/3). The fraction of the neutron leakage into Outside Region VII of Configuration (1/3, 2/3) per neutron incident on the shield was about 80% of the leakage into Outside Region VI of Configuration (1/2).

Based on the fact that twice as many of the neutrons leaving the source will enter the first shield segment of Configuration (1/3, 2/3) as will enter the shield in Configuration (1/2), it was found that about 40% more neutrons will enter Outside Region VII of Configuration (1/3, 2/3) as will enter Outside Region VI of Configuration (1/2).

The ratio of the leakages into Outside Region VI of Configuration (1/2) and Outside Region VII of Configuration (1/3, 2/3) is approximately the same as the ratio obtained from the expectation fluxes in the detector cavities of both configurations.

The differences in the magnitudes of the fluxes computed by the use of FMC-N and those shown in Table V, as well as the fact that the FMC-N results do not support the conclusions given in Reference 9, are disturbing. Because of the importance of the problem of obtaining a minimum-weight reactor shield for spacecraft applications, it is recommended that further work be performed to investigate the concept of split shielding.



#### IV. CONCLUSIONS AND RECOMMENDATIONS

##### 4.1 Radiator Scattering

For the particular type of spacecraft geometries treated in Section 2.4.2 of this report, it will be necessary to shield against the scattered neutrons as well as the direct-beam neutrons and gammas. The scattered neutrons, due to low-energy radiation leaking from the reactor, will be somewhat easier to shield against than the direct-beam neutrons. As can be seen from the results in Section 2.3.2, it will not be necessary for the reactor shield to be such that all parts of the radiator are shielded to the same degree. Considerable savings in weight can therefore be made by properly shaping the shield. It may also be possible to obtain a minimum-weight shield by placing shielding around the payload.

Since the scattered neutron flux is a significant component, improvements in the methods for calculating this component should be developed in order to remove some of the uncertainties discussed in Section 2.4.1.

With regard to the study of radiator scattering of neutrons, the following recommendations are made.

1. The effect of shielding should be considered. In particular, the possibility of obtaining a minimum-weight shield by proper shaping and placement should be investigated.
2. The methods of analysis should be improved by determining the importance of attenuation in the scattering calculations; if found to important, a method of including attenuation in the scattering calculations should be provided.

3. The development and use of improved methods for calculating neutron source terms should be considered.
4. Calculations should be performed to determine the secondary gamma fluxes due to neutron activation of the radiator. Program S06 can be used in its present form to carry out these calculations for both prompt and decay gammas.

#### 4.2 Direct-Beam Shielding

The following recommendations are made concerning the study of direct-beam shielding:

1. The effect of shield placement per se should be given further study.
2. The combined effects of splitting, expanding, and placement should be studied with realistic spacecraft geometries and SNAP reactor leakage spectra.
3. Direct-beam shielding should be considered in connection with radiator scattering, since the location of the direct-beam shielding could have a marked effect on the neutron flux incident on the radiators.
4. Effort should be directed toward resolving the apparent differences between TRG and GD/FW results for the split carbon shield discussed in Section 3.2. (This also points up the need for further study of shield-splitting, expansion, and placement.)

APPENDIX A  
FORTRAN STATEMENTS FOR S06



**FORTRAN Statements for S06**

```

*JOB 9242 86 JACK GRIGSBY (E E JONES 2895) S.N. 801184      0001 S06
* STRAP FORTRAN                                         0002 S06
* LIST8
CS06          JACK GRIGSBY (E E JONES 2895)             0003 S06
EZE  EZEC1 EZED2 EZED3 EOF  EZED5 EZEB1AEZEB3 EZEB4 EZEB1AEZEB5
      DIMENSION
      1SOURCE(15) ,PHIK(20) ,PHIK2(20) ,PHIL(15) ,PHI(20,15) ,
      0004 S06
      0005 S06
      0006 S06
C   2SUMLL(5) ,P(10) ,SX(100) ,SY(100) ,SIG(5) ,
      0007 S06
      0008 S06
C   3R1(20) ,ALPHA1(20),F(25,15,10),X0(20) ,YO(20) ,
      0009 S06
      0010 S06
C   4DELX(20) ,DELY (20),ATOM(5) ,SIGEL(15,25),S(15,20,20),
      0011 S06
      0012 S06
C   5NPX(20) ,NPY(20) ,KT(20) ,LLMAX(25) ,YLIB(5) ,
      0013 S06
      0014 S06
      COMMON
      1SOURCE ,PHIK ,PHIK2 ,PHIL ,PHI ,
      0015 S06
      0016 S06
      0017 S06
C   2SUMLL ,P ,SX ,SY ,SIG ,
      0018 S06
      0019 S06
C   3R1 ,ALPHA1 ,F ,XO ,YO ,
      0020 S06
      0021 S06
C   4DELX ,DELY ,ATOM ,SIGEL ,S ,
      0022 S06
      0023 S06
C   5NPX ,NPY ,KT ,LLMAX ,YLIB,
      0024 S06
      6XLIB ,L1 ,XLIBNO ,LIBNO ,XSLIB,
      0025 S06
      0026 S06
C   7LB ,YSLIB ,LBRD ,LBCK ,NU ,
      0027 S06
      0028 S06
C   8L ,XID
      0029 S06
      0030 S06
      COMMON
      1NA ,X1 ,Y1 ,DX ,NX ,NE ,THICK,NX1 ,VI ,X ,
      0031 S06
      0032 S06
      0033 S06
C   2DY ,NY ,NYM ,XNY ,SLOPE,NY1 ,VJ ,Y ,ALPHA,RSQ ,
      0034 S06
      0035 S06
C   3R ,DSQ ,SEP ,D ,THETA,FMU ,F1 ,PHIT ,FNPX ,XM ,
      0036 S06
      0037 S06
C   4FNPY ,YM ,MMAX ,NMAX ,CON1 ,CON2 ,CON3 ,CON4 ,LLMAX1 ,XLL ,
      0038 S06
      0039 S06
      5NUMAX,SIGMA
      READ IN LIBRARY DATA
      0040 S06
      0041 S06
      0042 S06
      0043 S06
      0044 S06
      LB=0
      CALL LIB1(L1)
      GO TO (10 ,1000 ) ,L1
      0045 S06
      0046 S06
      0047 S06
10  CALL LIB (3HS06 ,XLIBNO )
      0048 S06
      C   READ CONTROL CARD
      READ 20, LIBNO
      0049 S06
      0050 S06
20  FORMAT (6I10)
      IF. (LIBNO) 900 ,900 , 30
      0051 S06
      0052 S06
30  GO TO (35 ,200 ) , LIBNO
      0053 S06
      0054 S06

```

**FORTRAN Statements for S06 (Cont'd)**

```

C      READ IN SOURCE LIBRARY (TYPE 1 LIBRARY )          0055 S06
C
C      3 READ 40 ,NE ,MMAX , NMAX                      0056 S06
C      4 FORMAT  (3I10)                                 0057 S06
C      READ 45 , (R1(M) , M=1 ,MMAX )                 0058 S06
C      READ 45 , (ALPHA1 (N) , N=1 ,NMAX )             0059 S06
C      45 FORMAT  (6F10.3)                            0060 S06
C
C      DO 50   L=1 , NE                                0061 S06
C      DO 50   N=1 , NMAX                             0062 S06
C      READ 60 , ( S(L,M,N) , M = 1 , MMAX )           0063 S06
C      60 FORMAT  (1P6E10.3)                           0064 S06
C      50 CONTINUE                                     0065 S06
C      XSLIB = XLIBNO                                0066 S06
C      GO TO 10                                      0067 S06
C
C      READ IN CROSS SECTION DATA (TYPE 2 LIBRARIES ) 0068 S06
C      200 LB=LB+1                                    0069 S06
C
C      XLIB(LB) = XLIBNO                            0070 S06
C      READ 210, LLMAX(LB) , NE                     0071 S06
C      210 FORMAT  (2I10)                           0072 S06
C      READ 220, ( SIGEL(L,LB) , L=1, NE )            0073 S06
C      220 FORMAT  ( 1P6E10.3)                         0074 S06
C
C      LLMAXX=LLMAX(LB)                            0075 S06
C      DO 230   L=1 , NE                            0076 S06
C      READ 225 , (F(LB , L , LL) , LL=1 , LLMAXX)  0077 S06
C      225 FORMAT  ( 1P6E10.3)                         0078 S06
C      230 CONTINUE                                  0079 S06
C      GO TO 10                                      0080 S06
C
C
C
C      900 PRINT 910                                0081 S06
C      910 FORMAT (42H1 THE FOLLOWING LIBRARIES HAVE BEEN LOADED ) 0082 S06
C
C      PRINT 920 ,XSLIB ,( XLIB(I) ,I=1 , LB )        0083 S06
C      920 FORMAT (1H0 , 6F10.0)                      0084 S06
C
C      READ IN AND TEST PROBLEM CONTROL NUMBERS       0085 S06
C
C      BACKSPACE 9                                0086 S06
C      1000 CALL SETUP (3HS06 , XID )                0087 S06
C      READ 20 ,LIBNO                               0088 S06
C
C
C      READ 320 , NA ,      NUMAX ,LLMAX1 ,NE ,SLOPE 0089 S06
C      320 FORMAT  (4I10,F10.0 )                   0090 S06
C
C      READ 330 , SEP , YSLIB ,THICK               0091 S06
C      330 FORMAT  ( E10.4 , E10.4 , F10.0 )         0092 S06
C
C      READ 340 , (NPX(K) ,K=1,NA)                  0093 S06
C
C
C
C      0094 S06
C      0095 S06
C
C      0096 S06
C      0097 S06
C
C      0098 S06
C
C      0099 S06
C      0100 S06
C
C      0101 S06
C      0102 S06
C      0103 S06
C
C      0104 S06
C
C      0105 S06
C
C      0106 S06
C
C      0107 S06
C      0108 S06
C      0109 S06
C
C      0110 S06
C      0111 S06
C      0112 S06
C
C      0113 S06

```

### FORTRAN Statements for S06 (Cont'd)

```

      READ 340 , (NPY(K) ,K=1,NA)
      0114 S06
340 FORMAT (6I10)          0115 S06
      READ 340 ,(KT(K) ,K=1 ,NA )
      0116 S06
      READ 350 ,(X0(K) ,K=1 ,NA )
      0117 S06
      READ 350 ,(Y0(K) ,K=1 ,NA )
      0118 S06
      READ 350 ,(DELX (K) ,K=1 ,NA )
      0119 S06
      READ 350 ,(DELY (K) ,K=1 ,NA )
      0120 S06
350 FORMAT (6F10.3 )        0121 S06
      READ 360,(ATOM(NU) , NU=1, NUMAX )
      0122 S06
360 FORMAT (6E10.4)          0123 S06
      READ 370, , ( YLIB (NU) ,NU=1 ,NUMAX )
      0124 S06
370 FORMAT ( 6F10.3 )        0126 S06
C
C
      IF (XSLIB - YSLIB ) 9000 ,1100 ,9000
      0127 S06
9000 PRINT 9010
      0128 S06
9010 FORMAT (17H1 WRONG LIBRARY )
      0130 S06
      CALL END 9
      0131 S06
      0132 S06
      0134 S06
C
      1100 LBCK =0
      0135 S06
      DO 1160   I=1 , NUMAX
      0136 S06
      DO 1150   J=1 , LB
      0137 S06
      0138 S06
C
      IF (XLIB(J) -YLIB(I)) 1150 ,1140 ,1150
      0139 S06
1140 LBRD(I) = J
      0140 S06
      LBRD(I) = J
      0141 S06
      LBCK =LBCK + 1
      0142 S06
1150 CONTINUE
      0143 S06
1160 CONTINUE
      0144 S06
C
C
      IF (LBCK -NUMAX) 9100 ,1200 ,9100
      0145 S06
9100 PRINT 9110
      0146 S06
9110 FORMAT (52H1 LIBRARIES LOADED DO NOT AGREE WITH THOSE REQUESTED )
      0147 S06
      0148 S06
      0149 S06
C
C
      1200 CALL SUB M
      0150 S06
      PRINT 9250, PHIT
      0151 S06
      0152 S06
9250 FORMAT (29H TOTAL FLUX AT DETECTOR IS , 1P1E10.3 )
      0153 S06
      0154 S06
C
      PRINT 9260
      0155 S06
9260 FORMAT(43H0 FLUX SPECTRUM AT DETECTOR BY INCREASING L)
      0156 S06
      PRINT 9270,(PHIL(L) ,L=1, NE)
      0157 S06
      0158 S06
9270 FORMAT (1H0,1P6E10.3)
      0159 S06
C
      PRINT 9280
      0160 S06
9280 FORMAT(43H0 TOTAL FLUX FROM SUB AREAS BY INCREASING K)
      0161 S06
      PRINT 9290,(PHIK(K) ,K=1 ,NA )
      0162 S06
      0163 S06
9290 FORMAT (1H0,1P6E10.3)
      0164 S06
C
      PRINT 9300
      0165 S06
9300 FORMAT(39H0 FRACTION OF TOTAL FLUX FROM SUB AREAS)
      0166 S06
      PRINT 9310 , (PHIK2(K) ,K=1, NA )
      0170 S06
      0171 S06
9310 FORMAT (1H0,1P6E10.3)
      0172 S06
C
      DO 9311   K=1 , NA
      0173 S06
      PRINT 9312 ,K
      01731S06
      01732S06

```

**FORTRAN Statements for S06 (Cont'd)**

```

9312 FORMAT (36HO FLUX BY INCREASING I FOR SUB AREA ,12)          01733S06
  PRINT 9313, ( PHI (K,L) , L= 1, NE )                          01734S06
9313 FORMAT (1H0,1P6E10.3)                                         01735S06
9311 CONTINUE
  IF (ISENSE SWITCH 2 ). 9315 , 9375                           01736S06
9315 PRINT 9320
9320 FORMAT (48HO COORDINATES OF LOWER LEFT CORNER OF SUB AREAS )
  PRINT 9330
9330 FORMAT (37HO      K      X0(K)      Y0(K)      )
  PRINT 9340, (K ,X0(K) ,Y0(K) ,K=1 ,NA)                         0181 S06
9340 FORMAT (1H0, 17 ,1F14.2 , 1F11.2)
  PRINT 9370 , SEP
9370 FORMAT (42HO SOURCE DETECTOR SEPARATION DISTANCE IS ,1PE10.3 ) 0182 S06
9375 GO TO 1000
  END
* STRAP FORTRAN
* LIST8
CS06SBM           JACK GRIGSBY (E E JONES 2895)                  M001 S06
EZE   EZEC1 EZED2 EZED3 EOF   EZED5 EZEB1AEZEB3 EZEB4 EZEB1AEZEB5
SUBROUTINE SUBM
DIMENSION
 1SOURCE(15)    ,PHIK(20)  ,PHIK2(20)  ,PHIL(15)  ,PHI(20,15)  , 0005 S06
C   2SUMLL(5)    ,P(10)     ,SX(100)    ,SY(100)    ,SIG(5)     , 0006 S06
C   3R1(20)      ,ALPHA1(20),F(25,15,10),XO(20)    ,YO(20)     , 0007 S06
C   4DELX(20)    ,DELY (20),ATOM(5)    ,SIGEL(15,25),S(15,20,20) , 0008 S06
C   5NPX(20)     ,NPY(20)   ,KT(20)     ,LLMAX(25)  ,YLIB(5)   , 0009 S06
C   6XLIB(25),LBRD(5)
COMMON
 1SOURCE    ,PHIK    ,PHIK2    ,PHIL    ,PHI    , 0010 S06
C   2SUMLL    ,P       ,SX      ,SY      ,SIG    , 0011 S06
C   3R1       ,ALPHA1  ,F       ,XO      ,YO     , 0012 S06
C   4DELX     ,DELY   ,ATOM    ,SIGEL   ,S      , 0013 S06
C   5NPX      ,NPY    ,KT      ,LLMAX   ,YLIB   , 0014 S06
C   6XLIB     ,L1     ,XLIBNO  ,LIBNO   ,XSLIB  , 0015 S06
C   7LB        ,YSLIB  ,LBRD    ,LBCK    ,NU     , 0016 S06
C   8L1        ,XID    ,         ,        ,        , 0017 S06
C   COMMON
 1NA  ,X1  ,Y1  ,DX  ,NX  ,NE  ,THICK,NX1 ,VI  ,X  , 0018 S06
C   2DY  ,NY  ,NYM ,XNY ,SLOPE, NY1 ,VJ  ,Y  ,ALPHA,RSQ , 0019 S06
C   3R   ,DSQ ,SEP ,D   ,THETA,FMU ,F1  ,PHIT ,FNPX ,XM  , 0020 S06
C   4FNPY ,YM  ,MMAX ,NMAX ,CON1 ,CON2 ,CON3 ,CON4 ,LLMAX1 ,XLL , 0021 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0022 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0023 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0024 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0025 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0026 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0027 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0028 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0029 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0030 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0031 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0032 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0033 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0034 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0035 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0036 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0037 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0038 S06
C   ,        ,        ,        ,        ,        ,        ,        ,        , 0039 S06

```

### FORTRAN Statements for S06 (Cont'd)

```

5NUMAX,SIGMA          0040 S06
DO 9000 K=1 , NA      M042 S06
X1=X0(K)              M043 S06
Y1=Y0(K)              M044 S06
DX=DELX(K)             M045 S06
NX=NPX(K)              M046 S06
C                      M047 S06
DO 8100 L=1,NE         M048 S06
PHI(K,L)=0.0            M049 S06
8100 CONTINUE          M050 S06
C                      M051 S06
CALCULATE SX FOR ALL I M052 S06
C                      M053 S06
SX(1)= THICK *DX/3.0   M054 S06
SX(NX) =SX(1)           M055 S06
NX1=NX-1                M056 S06
DO 8200 I=2,NX1         M057 S06
VI=I                   M058 S06
SX(I)=SX(1)*(MODF(2.0*(VI+1.0),4.0)+2.0) M059 S06
8200 CONTINUE          M060 S06
M061 S06
C DO LOOP FOR SUMMING OVER X M062 S06
NPXX=NPX(K)             M063 S06
DO 8000 I=1,NPXX        M064 S06
VI=I                   M065 S06
X=X1+(VI-1.0)*DX       M066 S06
C GENERATE Y MESH       M067 S06
IF(KT(K)-1 )            7100 ,7200 ,7200 M068 S06
7100 DY=DELY(K)          M069 S06
NY=NPY(K)               M070 S06
GO TO 7300               M071 S06
C                         M072 S06
7200 NY=3+(I-1)*2       M073 S06
NYM=NY-1                 M074 S06
XNY=NYM                 M075 S06
DY=SLOPE*(X-X1)/XNY    M076 S06
NPY(K) = NY              M0761S06
GO TO 7300               M077 S06
C CALCULATE SY FOR ALL J M082 S06
7300 SY(1) =DY/3.0       M083 S06
SY(NY) = SY(1)            M0831S06
NY1=NY-1                 M084 S06
DO 7400 J=2,NY1          M085 S06
VJ =J                   M086 S06
SY(J) = SY(1) * (MODF(2.0 * (VJ+1.0), 4.0) + 2.0) M087 S06
7400 CONTINUE          M088 S06
NPYY = NPY(K)             M090 S06
DO 7000 J=1,NPYY         M091 S06
VJ=J                   M092 S06
Y=Y1+(VJ-1.0)*DY        M093 S06
C                         M094 S06
IF ( X ) 7310, 7320 , 7330 M095 S06
7310 ALPHA = 90.0 + ( ATANF (-X/Y ) ) * 57.296 M0952S06
GO TO 7311               M0953S06
7320 ALPHA = 90.0          M0955S06
GO TO 7311               M0956S06

```

**FORTRAN Statements for S06 (Cont'd)**

```

7330 ALPHA = ( ATANF (Y/X) ) * 57.296 M0958S06
      GO TO 7311 M0959S06
      M096 S06
      M097 S06
      M098 S06
      M099 S06
      M100 S06
      M101 S06
      M102 S06
      M103 S06
      M104 S06
      M106 S06
      M107 S06
      M108 S06
      M109 S06
      M110 S06
      M111 S06
      M112 S06
      M114 S06
      M115 S06
      M121 S06
      M122 S06
      M123 S06
      M124 S06
      M125 S06
      M126 S06
      M127 S06
      M128 S06
      M129 S06
      M130 S06
      M131 S06
      M132 S06
      M133 S06
      M134 S06
      M135 S06
      M136 S06
      M137 S06
      M138 S06
      M139 S06
      M140 S06
      M141 S06
      M142 S06
      M149 S06
      M150 S06
      M151 S06
      M152 S06
      M153 S06
      M154 S06
      M155 S06
      M156 S06
      M176 S06
      M177 S06
      1001 S06
      1002 S06
C   R      =SQRTF(RSQ)
      CALL SUB1 (K,I,J)
      DSQ    =RSQ + SEP**2 -2.0*SEP*X
C   SUB1 IS SOURCE CALCULATION
      D      =SQRTF(DSQ)
      FMU = ( SEP**2 - RSQ - DSQ ) / ( 2.0*R*D )
      F1     = SX(I)* SY(J)/DSQ
C   IF (SENSE SWITCH 3) 7430 , 6000
7430 PRINT 7435 ,K ,I ,J
7435 FORMAT (4H0 X,Y,ALPHA,R,D,THETA,FMU, AND F1 FOR K I J ,I5,I5,I5 )M110 S06
      PRINT 7440 ,X,Y,ALPHA,R,D,THETA,FMU, F1
7440 FORMAT (1H0,1P8E10.3)
      6000 CALL SUB2 (K,I,J)
C   SUB2 IS NEUTRON CALCULATION CONTAINS DO LOOP OVER ENERGY
      7000 CONTINUE
      8000 CONTINUE
      9000 CONTINUE
C
C   CALCULATE TOTAL AND FRACTIONAL FLUXES
7425 PHIT =0.0
      DO 9100 K=1 , NA
      PHIK(K) =0.0
C
      DO 9050 L=1 , NE
      PHIK(K) =PHIK(K) +PHI(L)
9050 CONTINUE
C
      PHIT =PHIT + PHIK(K)
9100 CONTINUE
C
      DO 9150 K=1 ,NA
C
      PHIK2(K) = PHIK(K)/PHIT
9150 CONTINUE
      DO 9200 L=1 ,NE
C
      PHI(L) =0.0
C
      DO 9175 K=1 , NA
C
      PHI(L) = PHI(L)+ PHI(K,L)
9175 CONTINUE
9200 CONTINUE
9207 RETURN
      END
* STRAP FORTRAN
* LIST8
CS06SB1      JACK GRIGSBY , E E JONES 28951
EZE  EZEC1 EZED2 EZED3 FOF  EZED5 EZFR1AEZEB3 EZEB4 EZEB1AEZEB5

```

**FORTRAN Statements for S06 (Cont'd)**

```

SUBROUTINE SUB1(K,I,J)                                2003 S06
DIMENSION
C   1SOURCE(15) ,PHIK(20) ,PHIK2(20) ,PHIL(15) ,PHI(20,15) , 0004 S06
C   2SUMLL(5)    ,P(10)     ,SX(100)    ,SY(100)    ,SIG(5)      , 0005 S06
C   3R1(20)      ,ALPHA1(20),F(25,15,10),X0(20)    ,Y0(20)      , 0006 S06
C   4DELX(20)    ,DELY(20),ATOM(5)      ,SIGEL(15,25),S(15,20,20), 0007 S06
C   5NPX(20)     ,NPY(20)    ,KT(20)     ,LLMAX(25)   ,YLIB(5)      , 0008 S06
C   6XLIB(25),LBRD(5)
COMMON
C   1SOURCE      ,PHIK      ,PHIK2      ,PHIL      ,PHI      ,
C   2SUMLL       ,P         ,SX         ,SY         ,SIG       ,
C   3R1          ,ALPHA1    ,F          ,X0        ,Y0        ,
C   4DELX         ,DELY     ,ATOM       ,SIGEL     ,S         ,
C   5NPX          ,NPY      ,KT         ,LLMAX    ,YLIB      ,
C   6XLIB         ,L1       ,XLIBNO    ,LIBNO    ,XSLIB      ,
C   7LB           ,YSLIB    ,LBRD      ,LBCK      ,NU        ,
C   8L1           ,XID      ,
COMMON
C   1NA          ,X1       ,Y1       ,DX       ,NX       ,NE       ,THICK,NX1 ,VI       ,X      ,
C   2DY          ,NY       ,NYM      ,XNY      ,SLOPE, NY1 ,VJ       ,Y       ,ALPHA,RSQ      ,
C   3R           ,DSQ      ,SEP      ,D        ,THETA,FMU ,F1       ,PHIT    ,FNPX ,XM      ,
C   4FNPY ,YM     ,MMAX    ,NMAX    ,CON1    ,CON2    ,CON3    ,CON4    ,LLMAX1 ,XLL      ,
C   5NUMAX,SIGMA
IF (R-R1(1)) 20, 2,2
2 IF (ALPHA -ALPHA1(1)) 20,5,5
C
5 DO 10 M=1 ,MMAX
IF (R1(M)-R ) 10 ,40 ,40
10 CONTINUE
20 PRINT 30
30 FORMAT ( 48H A VALUE OF R1 OR ALPHA1 CALLS FOR EXTRAPOLATION)
PRINT 31,K,L,I,J
10491S06
31 FORMAT (31HO X,Y,R,ALPHA FOR K,L,I,J OF 4I5 )
10492S06
PRINT 32, X,Y,R,ALPHA
10493S06
32 FORMAT (1HO ,1P4E10.3 )
10494S06
PRINT 33
10495S06
33 FORMAT (33HO MIN AND MAX INPUT R AND ALPHA )
PRINT 34, (R1(1),R1(MMAX),ALPHA1(1),ALPHA1(NMAX) )
10497S06
34 FORMAT (1HO ,1P4E10.3 )
10498S06
CALL AUTO
1050 S06
40 DO 50 N=1 • NMAX
1051 S06

```

**FORTRAN Statements for S06 (Cont'd)**

```

      IF (ALPHA1(N) = ALPHA)      50 ,60 ,60          1052 S06
50 CONTINUE
      GO TO 20
60 CON1 =(ALPHA-ALPHA1(N-1))/(ALPHA1(N)-ALPHA1(N-1))          1053 S06
C
      DO 100 L=1 ,NE
      CON3=S(L,M-1,N-1) +CON1*(S(L,M-1,N)-S(L,M-1,N-1))          1054 S06
C
      CON4=S(L,M,N-1) +CON1*(S(L,M,N)-S(L,M,N-1))          1055 S06
C
      SOURCE(L)=(CON3 * R1(M-1)**2+CON4 *R1(M)**2 ) / (2.0*R**2)          1056 S06
C
100 CONTINUE
      IF (SENSE SWITCH 4 )      65 ,110          1060 S06
C
      65 PRINT 70 , K , I , J          1061 S06
70 FORMAT (37HO SOURCES FOR ALL L FOR K I AND J OF,15 ,15 ,15 )          1062 S06
      PRINT 75 ,( SOURCE(L), L=1 , NE )          1063 S06
75 FORMAT ( 1P6E10.3)          1064 S06
C
110 RETURN          1065 S06
END          1066 S06
* STRAP FORTRAN          10661S06
* LIST8          1067 S06
          1068 S06
CS06SB2          JACK GRIGSBY (E E JONES 2895)          1069 S06
EZE          EZEC1 EZED2 EZED3 EOF EZED5 EZEB1AEZEB3 EZEB4 EZEB1AEZEB5          1070 S06
SUBROUTINE SUB2 (K,I,J)          1071 S06
DIMENSION
1SOURCE(15) ,PHIK(20) ,PHIK2(20) ,PHIL(15) ,PHI(20,15) ,          1072 S06
C
2SUMLL(5) ,P(10) ,SX(100) ,SY(100) ,SIG(5) ,          1073 S06
C
3R1(20) ,ALPHA1(20),F(25,15,10),X0(20) ,Y0(20) ,          1075 S06
C
4DELX(20) ,DELY (20),ATOM(5) ,SIGEL(15,25),S(15,20,20),          1076 S06
C
5NPX(20) ,NPY(20) ,KT(20) ,LLMAX(25) ,YLIB(5) ,          2001 S06
6XLIB(25),LBRD(5)
COMMON
1SOURCE ,PHIK ,PHIK2 ,PHIL ,PHI ,          2002 S06
C
2SUMLL ,P ,SX ,SY ,SIG ,          2003 S06
C
3R1 ,ALPHA1 ,F ,X0 ,Y0 ,          0004 S06
C
4DELX ,DELY ,ATOM ,SIGEL ,S ,          0005 S06
C
5NPX ,NPY ,KT ,LLMAX ,YLIB ,          0006 S06
6XLIB ,L1 ,XLIBNO ,LIBNO ,XSLIB ,          0007 S06
C
7LB ,YSLIB ,LBRD ,LBCK ,NU ,          0008 S06
C
8L1 ,XID ,          0009 S06
C
COMMON
1NA ,X1 ,Y1 ,DX ,NX ,NE ,THICK,NX1 ,VI ,X ,          0010 S06
          0011 S06
          0012 S06
          0013 S06
          0014 S06
          0015 S06
          0016 S06
          0017 S06
          0018 S06
          0019 S06
          0020 S06
          0021 S06
          0022 S06
          0023 S06
          0024 S06
          0025 S06
          0026 S06
          0027 S06
          0028 S06
          0029 S06
          0030 S06
          0031 S06
          0032 S06

```

### FORTRAN Statements for S06 (Cont'd)


```

C      2DY ,NY ,NYM ,XNY ,SLOPE,NY1 •VJ ,Y ,ALPHA•RSQ ,   0033 S06
C      3R ,DSQ ,SEP ,D ,THETA,FMU ,F1 ,PHIT ,FNPX ,XM ,   0034 S06
C      4FNPY ,YM ,MMAX ,NMAX ,CON1 ,CON2 ,CON3 ,CON4 ,LLMAX1 ,XLL , 0035 S06
C      5NUMAX,SIGMA
C      DIMENSION AND COMMON GO HERE
C      CALCULATE LEGENDRE COEFICIENTS FOR CROSS SECTION CALCULATION
C      P(1)=1.0
C      P(2)=FMU
C
C      IF (LLMAX1 -2) 100 ,100 ,60
60 DO 70 LL= 3 ,LLMAX1
      XLL=LL
C
C      P(LL) =((2.0*XLL-3.0) * FMU * P(LL-1) -(XLL-2.0)*P(LL-2))/ 2049 S06
1          (XLL-1.0) 2050 S06
C
C      70 CONTINUE
C      DO LOOP OVER ENERGY
100 DO 900 L=1 , NE
C
C      CALCULATE MICROSCOPIC CROSS SECTIONS SIG (NU)
C
C      DO 800 NUP=1 ,NUMAX
      NU = LBRD(NUP)
C
      SUMLL(NUP)=0.0
C
      LLM= LLMAX(NU)
      DO 790 LL=1 ,LLM
      XLL=LL
C
      SUMLL(NUP)=SUMLL(NUP)+(2.0*XLL-1.0)*F(NU,L,LL)*P(LL)/12.5664
790 CONTINUE
      SIG(NUP)= SIGEL(L,NU)* SUMLL(NUP)
C
      800 CONTINUE
C      CALCULATE MACROSCOPIC CROSS SECTIONS
      803 SIGMA =0.0
C
      DO 810 NU=1 , NUMAX
      SIGMA = SIGMA + ATOM(NU) * SIG(NU)
C
      810 CONTINUE
      PHI(K,L) = PHI(K,L)+SOURCE(L)*SIGMA *F1
C
      IF (SENSE SWITCH 6 ) 801 , 900
801 PRINT 802 , K ,I ,J ,L ,SIGMA
802 FORMAT (26H0 K I J L AND SIGMA ,I5,I5,I5,I5,1P1E10.3)
      PRINT 815
815 FORMAT (29H0 PHI(K,L) SOURCE(L) AND F1 )
      PRINT 820 ,PHI(K,L), SOURCE(L) * F1
820 FORMAT (1P3E10.3)

```



APPENDIX B  
INPUT AND OUTPUT FOR S06 SAMPLE PROBLEM



**Problem Data for S06**

6	1	9	10	0.58	53890100012	S06
913.0	509321.0	0.45			53890100022	S06
79	15	61	49	55	53890100032	S06
9	0	9	0	35	53890100042	S06
0	1	0	1	0	53890100052	S06
97.540	97.54	198.700	198.700	650.700	53890100062	S06
50.59	92.05	92.05	155.40	155.40	53890100072	S06
7.092	7.229	7.533	9.417	7.620	53890100082	S06
5.181	0.0	7.925	0.0	7.676	53890100092	S06
.0602+00					53890100102	S06
511223.0					53890100112	S06
					53890100122	S06

**Source Library for S06**

1							
10	5	5					
24.0	180.0	305.0	650.0	7000.0		5093210001L	S06
0.0	30.0	60.0	90.0	120.0		5093210002L	S06
2.72+06	2.18+04	7.24+03	1.53+03	1.32+01		5093210003L	S06
8.97+06	9.43+04	3.27+04	7.14+03	6.16+01		5093210004L	S06
6.83+06	1.11+05	3.92+04	8.65+03	7.46+01		5093210005L	S06
7.53+06	1.42+05	4.92+04	1.08+04	9.31+01		5093210006L	S06
6.83+06	1.11+05	3.92+04	8.65+03	7.46+01		5093210007L	S06
1.64+06	1.32+04	4.38+03	9.30+02	8.01+00		5093210008L	S06
2.57+06	2.62+04	9.08+03	1.98+03	1.71+01		5093210009L	S06
1.93+06	3.15+04	1.11+04	2.45+03	2.11+01		5093210010L	S06
2.20+06	4.11+04	1.43+04	3.12+03	2.69+01		5093210011L	S06
1.93+06	3.15+04	1.11+04	2.45+03	2.11+01		5093210012L	S06
1.02+06	8.34+03	2.77+03	5.89+02	4.33+00		5093210013L	S06
1.33+06	1.35+04	4.68+03	1.02+03	8.79+00		5093210014L	S06
9.90+05	1.62+04	5.70+03	1.26+03	1.09+01		5093210015L	S06
1.14+06	2.14+04	7.41+03	1.62+03	1.40+01		5093210016L	S06
9.90+05	1.62+04	5.70+03	1.26+03	1.09+01		5093210017L	S06
6.11+05	5.12+03	1.71+03	3.63+02	3.13+00		5093210018L	S06
2.76+05	2.81+03	9.69+02	2.11+02	1.82+00		5093210019L	S06
1.90+05	3.06+03	1.09+03	2.41+02	2.08+00		5093210020L	S06
2.27+05	4.31+03	1.49+03	3.26+02	2.81+00		5093210021L	S06
1.90+05	3.06+03	1.09+03	2.41+02	2.08+00		5093210022L	S06
3.55+05	3.04+03	1.01+03	2.16+02	1.87+00		5093210023L	S06
1.19+05	1.22+03	4.19+02	9.14+01	7.88-01		5093210024L	S06
8.30+04	1.34+03	4.72+02	1.06+02	9.14-01		5093210025L	S06
9.87+04	1.86+03	6.44+02	1.41+02	1.22+00		5093210026L	S06
8.30+04	1.34+03	4.72+02	1.06+02	9.14-01		5093210027L	S06
1.06+05	9.43+02	3.16+02	6.76+01	5.83-01		5093210028L	S06
2.82+04	2.87+02	9.87+01	2.15+01	1.85-01		5093210029L	S06
1.98+04	3.22+02	1.14+02	2.54+01	2.19-01		5093210030L	S06
2.38+04	4.46+02	1.54+02	3.37+01	2.91-01		5093210031L	S06
1.98+04	3.22+02	1.14+02	2.54+01	2.19-01		5093210032L	S06
3.18+04	3.69+02	1.27+02	2.77+01	2.39-01		5093210033L	S06
6.28+03	6.31+01	2.17+01	4.72+00	4.07-02		5093210034L	S06
4.44+03	7.26+01	2.58+01	5.73+00	4.94-02		5093210035L	S06
5.41+03	1.01+02	3.50+01	7.64+00	6.59-02		5093210036L	S06
4.44+03	7.26+01	2.58+01	5.73+00	4.94-02		5093210037L	S06
8.20+03	1.14+02	4.00+01	8.86+00	7.64-02		5093210038L	S06
1.35+03	1.35+01	4.62+00	1.00+00	8.62-03		5093210039L	S06
9.67+02	1.59+01	5.66+00	1.26+00	1.09-02		5093210040L	S06
1.19+03	2.23+01	7.70+00	1.68+00	1.45-02		5093210041L	S06
9.67+02	1.59+01	5.66+00	1.26+00	1.09-02		5093210042L	S06
2.54+02	2.41+00	8.15-01	1.76-01	1.51-03		5093210043L	S06
5.82+01	5.73-01	1.94-01	4.24-02	3.66-04		5093210044L	S06
4.28+01	7.06-01	2.54-01	5.63-02	4.85-04		5093210045L	S06
5.31+01	9.99-01	3.45-01	7.52-02	6.48-04		5093210046L	S06
4.28+01	7.06-01	2.53-01	5.63-02	4.85-04		5093210047L	S06
8.57+00	7.48-02	2.51-02	5.36-03	4.62-05		5093210048L	S06
1.92+00	1.86-02	6.27-03	1.37-03	1.18-05		5093210049L	S06
1.44+00	2.39-02	8.57-03	1.91-03	1.65-05		5093210050L	S06
1.81+00	3.42-02	1.18-02	2.57-03	2.22-05		5093210051L	S06
1.44+00	2.39-02	8.57-03	1.91-03	1.65-05		5093210052L	S06
						5093210053L	S06
						5093210054L	S06
					00054		

**Cross-Section Library for S06**

2							5112230001L	S06
9	10						5112230002L	S06
3.6+00	2.7+00	3.03+00	2.29+00	1.85+00	1.24+00		5112230003L	S06
0.86+00	0.67+00	0.69+00	0.85+00				5112230004L	S06
1.0+00	.082+00	.004+00	0.0+00	0.0+00	0.0+00		5112230005L	S06
0.0+00	0.0+00	0.0+00					5112230006L	S06
1.0+00	.256+00	.072+00	.004+00	0.0+00	0.0+00		5112230007L	S06
0.0+00	0.0+00	0.0+00					5112230008L	S06
1.0+00	.321+00	.115+00	.015+00	.004+00	0.0+00		5112230009L	S06
0.0+00	0.0+00	0.0+00					5112230010L	S06
1.0+00	.390+00	.175+00	.030+00	.015+00	.003+00		5112230011L	S06
0.0+00	0.0+00	0.0+00					5112230012L	S06
1.0+00	.449+00	.250+00	.049+00	.036+00	.013+00		5112230013L	S06
.003+00	0.0+00	0.0+00					5112230014L	S06
1.0+00	.530+00	.410+00	.182+00	.147+00	.062+00		5112230015L	S06
.022+00	.003+00	0.0+00					5112230016L	S06
1.0+00	.590+00	.482+00	.307+00	.242+00	.146+00		5112230017L	S06
.067+00	.016+00	0.0+00					5112230018L	S06
1.0+00	.622+00	.502+00	.365+00	.292+00	.208+00		5112230019L	S06
.112+00	.031+00	.006+00					5112230020L	S06
1.0+00	.680+00	.514+00	.422+00	.350+00	.288+00		5112230021L	S06
.201+00	.105+00	.036+00					5112230022L	S06
1.0+00	.709+00	.509+00	.432+00	.375+00	.305+00		5112230023L	S06
.237+00	.162+00	.077+00					5112230024L	S06
							00024	

**Output for S06**

GENERAL DYNAMICS/FORT WORTH S06 PROB      538901 DATE 8-27-62 PAGE 1

TOTAL FLUX AT DETECTOR IS      1.682+02

FLUX SPECTRUM AT DETECTOR BY INCREASING L

1.047+02    3.240+01    2.114+01    6.270+00    2.867+00    6.070-01

1.601-01    3.822-02    8.353-04    3.080-05

TOTAL FLUX FROM SUB AREAS BY INCREASING K

2.983+01    6.429+00    2.286+01    3.097+01    3.365+01    4.444+01

FRACTION OF TOTAL FLUX FROM SUB AREAS

1.774-01    3.823-02    1.359-01    1.841-01    2.001-01    2.643-01

FLUX BY INCREASING L FOR SUB AREA 1

1.639+01    6.335+00    4.624+00    1.438+00    7.393-01    2.152-01

6.789-02    1.763-02    4.380-04    1.674-05

FLUX BY INCREASING L FOR SUB AREA 2

4.196+00    1.240+00    7.973-01    1.367-01    5.075-02    6.988-03

7.371-04    8.219-05    1.122-06    4.058-08

FLUX BY INCREASING L FOR SUB AREA 3

1.318+01    4.763+00    3.363+00    9.595-01    4.581-01    1.056-01

2.620-02    5.727-03    1.007-04    2.981-06

FLUX BY INCREASING L FOR SUB AREA 4

2.075+01    5.672+00    3.526+00    7.056-01    2.747-01    3.544-02

4.572-03    6.658-04    1.700-05    8.611-07

FLUX BY INCREASING L FOR SUB AREA 5

2.457+01    5.242+00    2.886+00    6.687-01    2.419-01    3.184-02

6.982-03    1.689-03    4.209-05    1.650-06

FLUX BY INCREASING L FOR SUB AREA 6

2.561+01    9.145+00    5.942+00    2.362+00    1.102+00    2.120-01

5.376-02    1.243-02    2.363-04    8.523-06

APPENDIX C  
FORTRAN STATEMENTS FOR S14



### FORTRAN Statements for S14

```

*JOB 9247 86 JACK GRIGSBY (E E JONES 2895) S.N. 801184      0001 S14
* STRAP FORTRAN                                         0002 S14
* LIST8                                                 S14
CS14          JACK GRIGSBY (E E JONES 2895)             0003 S14
EZE  EZEC1 EZED2 EZED3 EOF   EZED5 EZEB1AEZEB3 EZEB4 EZEB1AEZEB5  S14
      DIMENSION                                         0004 S14
      1SOURCE(15), PHIK(20), PHIK2(20) , PHIL(15), PHI(20,15),SX(100), 0005 S14
C      2SY(100)   , R1(20)   , ALPHA1(20),X0(20)   , Y0(20)   , DELX(20), 0006 S14
C      3DELY(20)   , S(15,20,20),NPX(20)   , NPY(20)   , KT(20)   , EO(15)   , 0007 S14
C      4E(15)
      COMMON                                         0008 S14
      1SOURCE ,PHIK ,PHIK2 ,PHIL ,PHI ,SX ,SY ,R1 ,ALPHA1 ,X0, Y0, 0009 S14
C      2DELX   ,DELY ,S   ,NPX ,NPY   ,KT ,XLIB ,L1 ,XLIBNO ,LIBNO, 0010 S14
C      3XSLIB   ,LB   ,XID   ,NA   ,X1 ,Y1 ,DX ,NX ,NE ,THICK   ,NX1, 0011 S14
C      4VI   ,X   ,DY   ,NY   ,NYM   ,XNY   ,SLOPE   ,NY1,VJ   ,Y   ,ALPHA   ,RSQ , 0012 S14
C      5R   ,DSQ   ,SEP,D   ,FMU   ,F1   ,PHIT   ,FNPX   ,FNPY   , MMAX   ,NMAX   ,CON1   , 0013 S14
C      6CON2   ,CON3   ,CON4   ,CON5   ,CON6   ,CON7   ,CON8   , CON9   ,RO   ,CON10   , 0014 S14
C      7SIGMA   ,E1   ,EO   ,E   ,XNEL  0015 S14
C      READ IN LIBRARY DATA 0016 S14
C
      LB=0 0017 S14
      CALL LIB1(L1) 0018 S14
      GO TO (10,1000 ) ,L1 0019 S14
10     CALL LIB  (3HS14   ,XLIBNO ) 0020 S14
C      READ CONTROL CARD 0021 S14
      READ 20, LIBNO 0022 S14
20     FORMAT (6I10) 0023 S14
      IF (LIBNO) 900,900,35 0024 S14
C
C      READ IN SOURCE LIBRARY (TYPE 1 LIBRARY ) 0025 S14
C
35     READ 40 ,NE   ,MMAX   , NMAX 0026 S14
40     FORMAT (3I10) 0027 S14
      READ 45 , (R1(M)   , M=1 ,MMAX ) 0028 S14
      READ 45 , (ALPHA1 (N)   , N=1 ,NMAX ) 0029 S14
45     FORMAT (6F10.3) 0030 S14
      READ 360 ,(EO(L)   , L=1,NE) 0031 S14
360    FORMAT (6E10.4) 0032 S14
      READ 370 ,(E(L)   ,L=L ,NE) 0033 S14
370    FORMAT (6E10.4) 0034 S14
C
      DO 50   L=1 , NE 0035 S14
      DO 50   N=1 , NMAX 0036 S14
      READ 60 ,          ( S(L,M,N)   , M = 1 , MMAX ) 0037 S14
60     FORMAT (1P6E10.3) 0038 S14
50     CONTINUE 0039 S14

```

**FORTRAN Statements for S14 (Cont'd)**

```

XSLIB = XLIBNO          0068 S14
GO TO 10               0069 S14
900 PRINT 910           0093 S14
910 FORMAT (42H1 THE FOLLOWING LIBRARIES HAVE BEEN LOADED ) 0094 S14
C
C      PRINT 920 ,XSLIB ,( XLIB(I) , I=1 , LB ) 0095 S14
920 FORMAT (1H0 , 6F10.0) 0096 S14
C
C      READ IN AND TEST PROBLEM CONTROL NUMBERS 0097 S14
C
C      BACKSPACE 9 0098 S14
1000 CALL SETUP (3HS14 , XID ) 0099 S14
      READ 20 ,LIBNO 0100 S14
C
C
C      READ 320 ,NA,NE,SLOPE,SEP,YSLIB,THICK 0101 S14
320 FORMAT (2I10,4F10.0) 0102 S14
C
C      READ 330 ,XNEL 0103 S14
330 FORMAT ( 1P1E10.3) 0104 S14
C
C      READ 340 , (NPX(K) ,K=1,NA) 0105 S14
      READ 340 , (NPY(K) ,K=1,NA) 0106 S14
340 FORMAT (6I10) 0107 S14
      READ 340 ,(KT(K) ,K=1 ,NA ) 0108 S14
      READ 350 ,(XO(K) ,K=1 ,NA ) 0109 S14
      READ 350 ,(YO(K) ,K=1 ,NA ) 0110 S14
      READ 350 ,(DELX (K) ,K=1 ,NA ) 0111 S14
      READ 350 ,(DELY (K) ,K=1 ,NA ) 0112 S14
350 FORMAT (6F10.3 ) 0113 S14
C
C      R0 =.0000000000000000000000000000000079524 *XNEL 0114 S14
C
C      IF (XSLIB-YSLIB) 9000 ,1200 ,9000 0115 S14
9000 PRINT 9010          0116 S14
9010 FORMAT (17H1 WRONG LIBRARY ) 0117 S14
      CALL END 9 0118 S14
1200 CALL SUB M          0119 S14
      PRINT 9250, PHIT 0120 S14
9250 FORMAT (29H TOTAL FLUX AT DETECTOR IS , 1P1E10.3 ) 0121 S14
C
C      PRINT 9260          0122 S14
9260 FORMAT(43H0 FLUX SPECTRUM AT DETECTOR BY INCREASING L) 0123 S14
      PRINT 9270,(PHIL(L) ,L=1, NE) 0124 S14
9270 FORMAT (1H0,1P6E10.3) 0125 S14
C
C      PRINT 9280          0126 S14
9280 FORMAT(43H0 TOTAL FLUX FROM SUB AREAS BY INCREASING K) 0127 S14
      PRINT 9290,(PHIK(K) ,K=1 ,NA) 0128 S14
9290 FORMAT (1H0,1P6E10.3) 0129 S14
C
C      PRINT 9300          0130 S14
9300 FORMAT(39H0 FRACTION OF TOTAL FLUX FROM SUB AREAS) 0131 S14

```

**FORTRAN Statements for S14 (Cont'd)**

```

        PRINT 9310 , (PHIK2(K) , K=1, NA )          0171 S14
9310 FORMAT (1H0,1P6E10.3)                      0172 S14
C
        DO 9311 K=1 , NA                          0173 S14
        PRINT 9312 , K                           01731S14
9312 FORMAT (36H0 FLUX BY INCREASING L FOR SUB AREA ,I2) 01732S14
        PRINT 9313, ( PHI (K,L) , L= 1, NE )       01733S14
9313 FORMAT (1H0,1P6E10.3)                      01735S14
9311 CONTINUE                                     01736S14
        IF (SENSE SWITCH 2 ) 9315 , 9375          0174 S14
9315 PRINT 9320                                     0178 S14
9320 FORMAT (48H0 COORDINATES OF LOWER LEFT CORNER OF SUB AREAS ) 0179 S14
        PRINT 9330                                     0180 S14
9330 FORMAT (37H0      K      XO(K)      YO(K)      ) 0181 S14
        PRINT 9340, (K ,XO(K) ,YO(K) ,K=1 ,NA)       0182 S14
9340 FORMAT (1H0, I7 ,1F14.2 , 1F11.2)          0183 S14
        PRINT 9370 , SEP                         0192 S14
9370 FORMAT (42H0 SOURCE DETECTOR SEPARATION DISTANCE IS ,1PE10.3 ) 0193 S14
9375 GO TO 1000                                    0198 S14
        END                                         0199 S14
*      STRAP FORTRAN                         M001 S14
*      LIST8                                     S14
CS14SBM           JACK GRIGSBY (E E JONES 2895)  M002 S14
EZE   EZEC1 EZED2 EZED3 EOF   EZED5 EZEB1AEZEB3 EZEB4 EZEB1AEZEB5
      SUBROUTINE SUBM                         S14
      DIMENSION
      1SOURCE(15), PHIK(20), PHIK2(20) , PHIL(15), PHI(20,15),SX(100), 0005 S14
C
      2SY(100) , R1(20) , ALPHA1(20),XO(20) , YO(20) , DELX(20), 0006 S14
C
      3DELY(20) , S(15,20,20),NPX(20) ,NPY(20) , KT(20) , EO(15) , 0007 S14
C
      4E(15)
      COMMON
      1SOURCE ,PHIK ,PHIK2 ,PHIL ,PHI ,SX ,SY ,R1 ,ALPHA1 ,XO, YO, 0008 S14
C
      2DELX ,DELY ,S ,NPX ,NPY ,KT ,XLIB ,L1 ,XLIBNO ,LIBNO, 0009 S14
C
      3XSLIB ,LB ,XID ,NA ,X1 ,Y1 ,DX ,NX ,NE ,THICK ,NX1, 0010 S14
C
      4VI ,X ,DY ,NY ,NYM ,XNY ,SLOPE ,NY1,VJ ,Y ,ALPHA ,RSQ , 0011 S14
C
      5R ,DSQ ,SEP,D ,FMU ,F1 ,PHIT ,FNPX ,FNPY , MMAX ,NMAX ,CON1 , 0012 S14
C
      6CON2 ,CON3 ,CON4 ,CON5 ,CON6 ,CON7 ,CON8 , CON9 ,RO ,CON10 , 0013 S14
      7SIGMA ,E1 ,EO ,E ,XNEL
      DO 9000 K=1 , NA
      X1=XO(K)
      Y1=YO(K)
      DX=DELX(K)
      NX=NPX(K)
C
      DO 8100 L=1,NE
      PHI(K,L)=0.0

```

**FORTRAN Statements for S14 (Cont'd)**

```

8100 CONTINUE          M050 S14
C      CALCULATE SX FOR ALL I   M052 S14
C                                M053 S14
C      SX(1)= THICK      *DX/3.0   M054 S14
C      SX(NX) =SX(1)   M055 S14
C      NX1=NX-1        M056 S14
C      DO 8200 I=2,NX1    M057 S14
C      VI=1           M058 S14
C      SX(I)=SX(1)*(MODF(2.0*(VI+1.0),4.0)+2.0) M059 S14
8200 CONTINUE          M060 S14
C
C      DO LOOP FOR SUMMING OVER X   M061 S14
C      NPXX=NPX(K)   M062 S14
C      DO 8000 I=1,NPXX   M063 S14
C      VI=I           M064 S14
C      X=X1+(VI-1.0)*DX   M065 S14
C      GENERATE Y MESH   M066 S14
C      IF(KT(K)-1)      7100 ,7200 ,7200   M067 S14
7100 DY=DELY(K)       M068 S14
NY=NPY(K)             M069 S14
GO TO 7300            M070 S14
M071 S14
C
C      7200 NY=3+(I-1)*2   M072 S14
NYM=NY-1              M073 S14
XNY=NYM              M074 S14
DY=SLOPE*(X-X1)/XNY   M075 S14
NPY(K) = NY           M076 S14
GO TO 7300            M0761S14
M077 S14
C      CALCULATE SY FOR ALL J   M082 S14
7300 SY(1) =DY/3.0    M083 S14
SY(NY) = SY(1)         M0831S14
NY1=NY-1              M084 S14
DO 7400 J=2,NY1       M085 S14
VJ =J                 M086 S14
SY(J) = SY(1) * (MODF(2.0 * (VJ+1.0), 4.0) + 2.0) M087 S14
7400 CONTINUE          M088 S14
NPYY = NPY(K)          M090 S14
DO 7000 J=1,NPYY       M091 S14
VJ=J                 M092 S14
Y=Y1+(VJ-1.0)*DY     M093 S14
C
C      IF ( X ) 7310, 7320 , 7330   M094 S14
7310 ALPHA = 90.0 + ( ATANF (-X/Y) ) * 57.296   M095 S14
GO TO 7311            M0952S14
M0953S14
7320 ALPHA = 90.0       M0955S14
GO TO 7311            M0956S14
7330 ALPHA = ( ATANF (Y/X) ) * 57.296   M0958S14
GO TO 7311            M0959S14
C
C      7311 RSQ          =X**2 + Y**2   M096 S14
C
R                  =SQRTF(RSQ)   M097 S14
CALL SUB1 (K,I,J)     M098 S14
DSQ                =RSQ + SEP**2 -2.0*SEP*X   M099 S14
M100 S14
M101 S14

```

**FORTRAN Statements for S14 (Cont'd)**

```

C      SUB1 IS SOURCE CALCULATION                                M102 S14
D          =SQRTF(DSQ)                                         M103 S14
FMU = ( SEP**2 - RSQ - DSQ ) / ( 2.0*R*D)                   M104 S14
F1      = SX(I)* SY(J)/DSQ                                     M106 S14
C
C      IF (SENSE SWITCH 3) 7430 , 6000                           M107 S14
7430 PRINT 7435 ,K ,I ,J                                       M108 S14
7435 FORMAT (44HO X,Y,ALPHA,R,D,THETA,FMU, AND F1 FOR K I J ,I5,I5,I5) M110 S14
PRINT 7440 ,X,Y,ALPHA,R,D,THETA,FMU, F1                      M111 S14
7440 FORMAT (1H0,1P8E10.3)                                      M112 S14
6000 CALL SUB2 (K,I,J)                                         M114 S14
C      SUB2 IS GAMMA CALCULATION CONTAINS DO LOOP OVER ENERGY   M115 S14
7000 CONTINUE                                                 M121 S14
8000 CONTINUE                                                 M122 S14
9000 CONTINUE                                                 M123 S14
C
C
C      CALCULATE TOTAL AND FRACTIONAL FLUXES                    M124 S14
7425 PHIT =0.0                                              M127 S14
DO 9100 K=1 , NA                                           M128 S14
PHIK(K) =0.0                                                 M129 S14
C
DO 9050 L=1 , NE                                           M130 S14
PHIK(K) =PHIK(K) +PHI(L)                                    M131 S14
9050 CONTINUE                                               M132 S14
C
PHIT =PHIT + PHI(K)                                       M133 S14
9100 CONTINUE                                               M134 S14
C
DO 9150 K=1 ,NA                                           M135 S14
C
PHIK2(K) = PHI(K)/PHIT                                     M136 S14
9150 CONTINUE                                               M137 S14
DO 9200 L=1 ,NE                                           M138 S14
C
PHIL(L) =0.0                                                 M139 S14
C
DO 9175 K=1 , NA                                         M140 S14
C
PHIL(L) = PHIL(L)+ PHI(K,L)                                M141 S14
9175 CONTINUE                                               M142 S14
9200 CONTINUE                                               M143 S14
9207 RETURN                                                 M144 S14
END
*      STRAP FORTRAN                                         1001 S14
*      LIST8                                                 S14
CS14SB1           JACK GRIGSBY ,E E JONES 2895)             1002 S14
EZE  EZEC1 EZED2 EZED3 EOF     EZED5 EZEB1AEZEB3 EZEB4 EZEB1AEZEB5  S14
      SUBROUTINE SUB1(K,I,J)                                 2003 S14
      DIMENSION
      1SOURCE(15), PHI(K,20), PHI2(20) , PHI(L,15), PHI(20,15),SX(100), 0004 S14
C
      2SY(100) , R1(20) , ALPHA1(20),X0(20) , Y0(20) , DELX(20), 0005 S14
C
      0006 S14
C
      0007 S14
C
      0008 S14

```

### FORTRAN Statements for S14 (Cont'd)

```

C      3DELY(20) , S(15,20,20),NPX(20) ,NPY(20) , KT(20) , EO(15) , 0009 S14
C      4E(15) 0010 S14
C      COMMON 0011 S14
C      1SOURCE ,PHIK ,PHIK2 ,PHIL ,PHI ,SX ,SY ,R1 ,ALPHA1 ,XO, YO, 0015 S14
C      2DELX ,DELY ,S ,NPX ,NPY ,KT ,XLIB ,L1 ,XLIBNO ,LIBNO, 0016 S14
C      3XSLIB ,LB ,XID ,NA ,X1 ,Y1 ,DX ,NX ,NE ,THICK ,NX1, 0017 S14
C      4VI ,X ,DY ,NY ,NYM ,XNY ,SLOPE ,NY1,VJ ,Y ,ALPHA ,RSQ , 0018 S14
C      5R ,DSQ ,SEP,D ,FMU ,F1 ,PHIT ,FNPX ,FNPY , MMAX ,NMAX ,CON1 , 0019 S14
C      6CON2 ,CON3 ,CON4 ,CON5 ,CON6 ,CON7 ,CON8 , CON9 ,RO ,CON10 , 0020 S14
C      7SIGMA ,E1 ,EO ,E ,XNEL 0021 S14
C      IF (R-R1(1)) 20, 2,2 0022 S14
C      2 IF (ALPHA -ALPHA1(1)) 20,5,5 0023 S14
C
C      5 DO 10 M=1 ,MMAX 0024 S14
C      IF (R1(M)-R ) 10 ,40 ,40 0025 S14
C      10 CONTINUE 1042 S14
C      20 PRINT 30 1043 S14
C      30 FORMAT ( 48H A VALUE OF R1 OR ALPHA1 CALLS FOR EXTRAPOLATION) 1044 S14
C      PRINT 31,K,L,I,J 1045 S14
C      31 FORMAT (31HO X,Y,R,ALPHA FOR K,L,I,J OF 415 ) 1046 S14
C      PRINT 32, X,Y,R,ALPHA 1047 S14
C      32 FORMAT (1HO ,1P4E10.3 ) 1048 S14
C      PRINT 33 1049 S14
C      33 FORMAT (33HO MIN AND MAX INPUT R AND ALPHA ) 10491S14
C      PRINT 34, (R1(1),R1(MMAX),ALPHA1(1),ALPHA1(NMAX) ) 10492S14
C      34 FORMAT (1HO ,1P4E10.3) 10493S14
C      CALL AUTO 10494S14
C      40 DO 50 N=1 , NMAX 10495S14
C      IF (ALPHA1(N) -ALPHA) 50 ,60 ,60 10496S14
C      50 CONTINUE 10497S14
C      GU TU 20 10498S14
C      60 CON1 =(ALPHA-ALPHA1(N-1))/(ALPHA1(N)-ALPHA1(N-1)) 10499S14
C
C      DO 100 L=1 ,NE 1050 S14
C      CON3=S(L,M-1,N-1) +CON1*(S(L,M-1,N)-S(L,M-1,N-1)) 1051 S14
C
C      CON4=S(L,M,N-1) +CON1*(S(L,M,N)-S(L,M,N-1)) 1052 S14
C
C      SOURCE(L)=(CON3 * R1(M-1)**2+CON4 *R1(M)**2 ) / (2.0*R**2) 1053 S14
C
C      100 CONTINUE 1054 S14
C      IF (SENSE SWITCH 4 ) 65 ,110 1055 S14
C
C      65 PRINT 70 , K , I , J 1056 S14
C      70 FORMAT (37HO SOURCES FOR ALL L FOR K I AND J OF,I5 ,I5 ,I5 ) 1060 S14
C      PRINT 75 , ( SOURCE(L), L=1 , NE ) 1061 S14
C      75 FORMAT ( 1P6E10.3) 1062 S14
C
C      10661S14
C      1067 S14
C      1068 S14
C
C      1069 S14
C      1070 S14
C      1071 S14
C      1072 S14
C      1073 S14

```

### FORTRAN Statements for S14 (Cont'd)

```

110 RETURN          1075 S14
      ENU          1076 S14
*   STRAP FORTRAN  2002 S14
*   LIST8          S14
CS14S82           JACK GRIGSBY (E E JONES 2896)  2003 S14
EZE   EZEC1 EZED2 EZED3 EOF   EZED5 EZEB1AEZEB3 EZEB4 EZEB1AEZEB5  S14
      SUBROUTINE SUB2 (K,I,J)  2004 S14
      DIMENSION  00041S14
      1SOURCE(15), PHIK(20), PHIK2(20) , PHIL(15), PHI(20,15),SX(100), 0005 S14
C      2SY(100)    , R1(20)    , ALPHA1(20),X0(20) . , Y0(20)    , DELX(20), 0006 S14
C      3DELY(20)    , S(15,20,20),NPX(20) ,NPY(20) , KT(20)    , E0(15)    , 0007 S14
C      0008 S14
C      0009 S14
C      0010 S14
C      4E(15)
      COMMON  0011 S14
      1SOURCE ,PHIK ,PHIK2 ,PHIL ,PHI ,SX ,SY ,R1 ,ALPHA1 ,X0, Y0, 0015 S14
C      0016 S14
C      2DELX    ,DELY ,S    ,NPX ,NPY ,KT ,XLIB ,L1 ,XLIBNO ,LIBNO, 0017 S14
C      0018 S14
C      3XSLIB    ,LB    ,XID    ,NA    ,X1    ,Y1    ,DX    ,NX    ,NE    ,THICK    ,NX1, 0019 S14
C      0020 S14
C      4VI    ,X    ,DY    ,NY    ,NYM    ,XNY    ,SLOPE    ,NY1,VJ    ,Y    ,ALPHA    ,RSQ    , 0021 S14
C      0022 S14
C      5R    ,DSQ    ,SEP,D    ,FMU    ,F1    ,PHIT    ,FNPX    ,FNPY    ,MMAX    ,NMAX    ,CON1    , 0023 S14
C      0024 S14
C      0025 S14
C      6CON2    ,CON3    ,CON4    ,CONS    ,CON6    ,CON7    ,CON8    ,CON9    ,RO    ,CON10    , 0026 S14
C      7SIGMA    ,E1    ,E0    ,E    ,XNEL  0027 S14
C      DO LOOP OVER ENERGY  2029 S14
C      2030 S14
C      DO 600    L=1    ,NE  2031 S14
C      2032 S14
C      CALCULATE SIGMA  2033 S14
C      CON7 = E0(L)/0.51  2035 S14
C      CON6 = 1.0 / (1.0 + CON7*( 1.0 - FMU) )  2036 S14
C      SIGMA = RO * ( CON6 - ( CON6**2)*(1.0-FMU**2) + CON6**3 ) / 2.0  2038 S14
C      CALCULATE FINAL ENERGY  2040 S14
C      E1 = CON7*CON6 * 0.51  2042 S14
C      2054 S14
C      DETERMINE WHICH GROUP E1 LIES IN AND CALCULATE PHI  2055 S14
C      2056 S14
C      DO 610    LF= 1, NE  2057 S14
C      2058 S14
C      IF ( E(LF)-E1 )    620 , 620 , 610  2059 S14
610 CONTINUE  2060 S14
C      2061 S14
C      2062 S14
C      620 PHI (K,LF)= PHI (K,LF)+ SOURCE(L) * SIGMA    * F1  2063 S14
      IF (SENSE SWITCH 6)  630,600  20631S14
C      630 PRINT 635  20632S14
C      635 FORMAT (30H0 K I J L E1 SIGMA AND SOURCE )  20633S14
      PRINT 640 ,K,I,J,L,E1,SIGMA,SOURCE(L)  20634S14
C      640 FORMAT ( 4I5,1P3E10.3)  20635S14
C      2064 S14

```

**FORTRAN Statements for S14 (Cont'd)**


600 CONTINUE  
RETURN  
END

2065 S14  
2066 S14  
2067 S14

00381

APPENDIX D

INPUT AND OUTPUT FOR S14 SAMPLE PROBLEM



**Problem Data for S14**

6	14	0.58	913.0	529621.0	0.45	56430300012	S14
0.782+24						56430300022	S14
						56430300032	S14
79	15	61	49	55	45	56430300042	S14
9	0	9	0	35	15	56430300052	S14
0	1	0	1	0	0	56430300062	S14
97.54	97.54	198.70	198.700	650.7	650.700	56430300072	S14
50.59	92.05	92.05	155.40	155.4	50.590	56430300082	S14
7.092	7.229	7.533	9.417	7.620	7.2390	56430300092	S14
5.181	0.0	7.925	0.0	7.676	7.4930	56430300102	S14

**Source Library for S14**

1							5296210001L	S14
14	5	5					5296210002L	S14
24.0	180.0	305.0	650.0	7000.0			5296210003L	S14
0.0	30.0	60.0	90.0	120.0			5296210004L	S14
9.34+00	8.25+00	7.51+00	6.43+00	5.43+00	4.39+00		5296210005L	S14
3.36+00	2.37+00	1.72+00	1.20+00	8.59-01	6.09-01		5296210006L	S14
3.45-01	1.17-01						5296210007L	S14
9.00+00	8.00+00	7.00+00	6.00+00	5.00+00	4.00+00		5296210008L	S14
3.00+00	2.00+00	1.50+00	1.00+00	7.50-01	5.00-01		5296210009L	S14
2.50-01	0.00+00						5296210010L	S14
1.79+03	1.40+01	4.60+00	9.81-01	8.45-03			5296210011L	S14
4.37+02	8.36+00	2.97+00	6.60-01	5.70-03			5296210012L	S14
9.36+02	1.47+01	5.15+00	1.13+00	9.76-03			5296210013L	S14
1.03+03	1.78+01	6.15+00	1.35+00	1.16-02			5296210014L	S14
9.36+02	1.47+01	5.15+00	1.13+00	9.76-03			5296210015L	S14
1.92+04	1.50+02	4.95+01	1.05+01	9.10-02			5296210016L	S14
4.69+03	8.97+01	3.19+01	7.08+00	6.11-02			5296210017L	S14
1.00+04	1.58+02	5.53+01	1.21+01	1.05-01			5296210018L	S14
1.09+04	1.91+02	6.60+01	1.45+01	1.25-01			5296210019L	S14
1.00+04	1.58+02	5.53+01	1.21+01	1.05-01			5296210020L	S14
3.40+04	2.65+02	8.75+01	1.86+01	1.60-01			5296210021L	S14
8.29+03	1.59+02	5.64+01	1.25+01	1.08-01			5296210022L	S14
1.78+04	2.80+02	9.78+01	2.15+01	1.85-01			5296210023L	S14
1.93+04	3.38+02	1.17+02	2.56+01	2.21-01			5296210024L	S14
1.78+04	2.80+02	9.78+01	2.15+01	1.85-01			5296210025L	S14
4.67+04	3.65+02	1.20+02	2.56+01	2.21-01			5296210026L	S14
1.14+04	2.18+02	7.75+01	1.72+01	1.49-01			5296210027L	S14
2.44+04	3.85+02	1.35+02	2.95+01	2.55-01			5296210028L	S14
2.66+04	4.65+02	1.60+02	3.52+01	3.03-01			5296210029L	S14
2.44+04	3.85+02	1.35+02	2.95+01	2.55-01			5296210030L	S14
8.12+04	6.33+02	2.09+02	4.45+01	3.83-01			5296210031L	S14
1.98+04	3.79+02	1.35+02	2.99+01	2.58-01			5296210032L	S14
4.24+04	6.68+02	2.33+02	5.13+01	4.43-01			5296210033L	S14
4.61+04	8.08+02	2.79+02	6.11+01	5.27-01			5296210034L	S14
4.24+04	6.68+02	2.33+02	5.13+01	4.43-01			5296210035L	S14
1.62+05	1.27+03	4.18+02	8.90+01	7.67-01			5296210036L	S14
3.96+04	7.59+02	2.69+02	5.99+01	5.17-01			5296210037L	S14
8.49+04	1.34+03	4.67+02	1.03+02	8.86-01			5296210038L	S14
9.24+04	1.62+03	5.58+02	1.22+02	1.05+00			5296210039L	S14
8.49+04	1.34+03	4.67+02	1.03+02	8.86-01			5296210040L	S14
4.51+05	3.52+03	1.16+03	2.47+02	2.13+00			5296210041L	S14
1.10+05	2.11+03	7.49+02	1.66+02	1.44+00			5296210042L	S14
2.36+05	3.72+03	1.30+03	2.85+02	2.46+00			5296210043L	S14
2.57+05	4.49+03	1.55+03	3.40+02	2.93+00			5296210044L	S14
2.36+05	3.72+03	1.30+03	2.85+02	2.46+00			5296210045L	S14
1.40+06	1.09+04	3.60+03	7.66+02	6.60+00			5296210046L	S14
3.41+05	6.53+03	2.32+03	5.15+02	4.45+00			5296210047L	S14
7.31+05	1.15+04	4.02+03	8.83+02	7.62+00			5296210048L	S14
7.94+05	1.39+04	4.80+03	1.05+03	9.07+00			5296210049L	S14
7.31+05	1.15+04	4.02+03	8.83+02	7.62+00			5296210050L	S14
1.39+06	1.09+04	3.59+03	7.65+02	6.55+00			5296210051L	S14
3.40+05	6.50+03	2.31+03	5.15+02	4.43+00			5296210052L	S14
7.30+05	1.15+04	4.00+03	8.80+02	7.60+00			5296210053L	S14
7.94+05	1.39+04	4.80+03	1.05+03	9.07+00			5296210054L	S14

**Source Library for S14 (Cont'd)**

7.30+05	1.15+04	4.00+03	8.80+02	7.60+00	5296210055L	S14
2.28+06	1.78+04	5.85+03	1.25+03	1.08+01	5296210056L	S14
5.55+05	1.07+04	3.78+03	8.40+02	7.25+00	5296210057L	S14
1.19+06	1.88+04	6.55+03	1.44+03	1.24+01	5296210058L	S14
1.30+06	2.27+04	7.80+03	1.73+03	1.48+01	5296210059L	S14
1.19+06	1.88+04	6.55+03	1.44+03	1.24+01	5296210060L	S14
1.81+06	1.41+04	4.68+03	9.93+02	8.55+00	5296210061L	S14
4.42+05	8.48+03	3.00+03	6.68+02	5.78+00	5296210062L	S14
9.48+05	1.49+04	5.23+03	1.15+03	9.88+00	5296210063L	S14
1.03+06	1.80+04	6.23+03	1.36+03	1.18+01	5296210064L	S14
9.48+05	1.49+04	5.23+03	1.15+03	9.88+00	5296210065L	S14
3.10+06	2.42+04	7.90+03	1.70+03	1.46+01	5296210066L	S14
7.55+05	1.45+04	5.15+03	1.14+03	9.85+00	5296210067L	S14
1.62+06	2.55+04	8.93+03	1.96+03	1.69+01	5296210068L	S14
1.76+06	3.08+04	1.07+04	2.33+03	2.01+01	5296210069L	S14
1.62+06	2.55+04	8.93+03	1.96+03	1.67+01	5296210070L	S14
7.53+06	5.89+04	1.94+04	4.13+03	3.55+01	5296210071L	S14
1.84+06	3.53+04	1.64+04	2.78+03	2.40+01	5296210072L	S14
3.93+06	6.20+04	2.17+04	4.75+03	4.10+01	5296210073L	S14
4.28+06	7.48+04	2.58+04	5.65+03	4.89+01	5296210074L	S14
3.93+06	6.20+04	2.17+04	4.75+03	4.10+01	5296210075L	S14
1.09+07	8.50+04	2.80+04	5.98+03	5.15+01	5296210076L	S14
2.65+06	5.10+04	1.81+04	4.03+03	3.48+01	5296210077L	S14
5.70+06	8.98+04	3.13+04	6.88+03	5.95+01	5296210078L	S14
6.20+06	1.08+05	3.75+04	8.20+03	7.08+01	5296210079L	S14
5.70+06	8.98+04	3.13+04	6.88+03	5.95+01	5296210080L	S14
					00080	

**Output for S14**

GENERAL DYNAMICS/FORT WORTH S14 PROB      564303 DATE  8-29-62 PAGE  1

TOTAL FLUX AT DETECTOR IS      4.798+02

FLUX SPECTRUM AT DETECTOR BY INCREASING L

0.	0.	0.	1.510-04	1.165-02	6.799-02
2.737-01	2.011+00	5.183+00	1.520+01	1.736+01	3.834+01
1.329+02	2.685+02				

TOTAL FLUX FROM SUB AREAS BY INCREASING K

9.832+01	1.024+01	6.852+01	5.376+01	6.740+01	1.816+02
----------	----------	----------	----------	----------	----------

FRACTION OF TOTAL FLUX FROM SUB AREAS

2.049-01	2.135-02	1.428-01	1.120-01	1.405-01	3.785-01
----------	----------	----------	----------	----------	----------

FLUX BY INCREASING L FOR SUB AREA 1

0.	0.	0.	1.510-04	1.151-02	6.374-02
2.300-01	1.511+00	3.173+00	7.489+00	5.808+00	1.115+01
2.800+01	4.089+01				

FLUX BY INCREASING L FOR SUB AREA 2

0.	0.	0.	0.	0.	0.
0.	4.261-04	1.256-02	2.464-01	4.631-01	8.175-01
3.874+00	4.830+00				

FLUX BY INCREASING L FOR SUB AREA 3

0.	0.	0.	0.	0.	0.
6.780-03	2.125-01	9.454-01	3.059+00	3.980+00	8.274+00
2.175+01	3.030+01				

FLUX BY INCREASING L FOR SUB AREA 4

0.	0.	0.	0.	0.	0.
0.	0.	1.169-02	5.019-01	1.612+00	4.126+00
1.908+01	2.843+01				

FLUX BY INCREASING L FOR SUB AREA 5


**Output for S14 (Cont'd)**

GENERAL DYNAMICS/FORT WORTH S14 PROB      564303 DATE  8-29-62 PAGE  2

0.	0.	0.	0.	0.	0.
0.	0.	1.190-07	1.726-02	2.261-01	1.551+00
1.209+01	5.351+01				

FLUX BY INCREASING L FOR SUB AREA  6

0.	0.	0.	0.	1.377-04	4.251-03
3.699-02	2.868-01	1.040+00	3.886+00	5.270+00	1.242+01
4.810+01	1.106+02				



APPENDIX E  
MACHINE OPERATING INSTRUCTIONS FOR PROCEDURES  
S06 AND S1<sup>4</sup>

APPENDIX E  
MACHINE OPERATING INSTRUCTIONS FOR PROCEDURES  
S06 and S14

The computer codes S06 and S14 (procedures) are designed to run in STRAP, the GD/FW operating system for the IBM-7090. In the modified version of the 709/7090 FORTRAN System used at GD/FW, the STRAP System is read from the system tape and control transferred to it whenever a STRAP control card is encountered by either SIGNON or SCAN. At the end of a STRAP job, the FORTRAN Common I-O Package is stored and control returned to SIGNON.

A method by which computing installations other than GD/FW may run a computer code designed for use with STRAP as a standard execute job in the 709/7090 FORTRAN System has been developed. The job deck for running in this mode is composed of the following parts in the order listed:

1. DATE card and/or I.D. card compatible with the version of the 709/7090 FORTRAN System used by the installation running the job.
2. Any FORTRAN Monitor comment or PAUSE cards needed by the individual computing installation.
3. The STRAP control deck, which is numbered consecutively in Columns 73-75, beginning with 001, and has STRP2 in Columns 76-80 of each card. Card 001 is an EXQ control card.
4. The program binary deck for the computer code in question. This deck is numbered consecutively in Columns 73-76, beginning at 0001, and has the computer code identification in Columns 78-80 of each card.
5. Problem-data decks and library-data decks.

The following statements should convey to anyone familiar with the basic 709/7090 FORTRAN System all the information needed to run a STRAP job:

1. The job deck is written as a file on the input tape. When the FORTRAN Monitor reaches this file, control is transferred to the STRAP Monitor via the XEQ card, and the STRAP Monitor in turn transfers control to the specific computer code being run.
2. Tapes A1, A2, and A3 are the system, input, and output tapes in STRAP, just as in the FORTRAN system. B4 is written on by the FORTRAN Monitor and hence must not be filed protected.
3. Tape B1 is used as an intermediate tape.
4. The memory locations between  $(3)_8$  and  $(143)_8$  permanently reserved for the use of the FORTRAN Monitor are not used by STRAP procedures.
5. Programmed stops in STRAP procedures are preceded by a comment on the on-line printer.
6. The output added to tape A3 by STRAP jobs will not be followed by an end-of-file.
7. Upon completion of a STRAP run, the system tape on A1 is rewound, the FORTRAN Common I-O Package is read in, two Monitor records (DUMP and C-to-tape) are skipped on A1, and (LOAD) is called to bring in SIGNON.
8. Tapes are assigned in STRAP jobs according to the following table:

<u>Logical No. or Tape Function</u>	<u>Actual 7090 Tape Assignment</u>
1	B1
2	B2
3	B3
4	B4
5	B5
6	B6
7	A4
8	A5
9, READ	A2
10, PRINT	A3
11	A6
12	A5
SYSTEM	A1

The actual 7090 tape assignment corresponding to logical tape numbers 1, 2, 3, 4, 5, 6, 7, 11, or 12 may be altered by the using installation. The choice of tape units must, however, be limited to channels A, B, or C. The following is an octal listing of the STRAP tape unit table.

77643	000000000024		
44	2201	LOGICAL TAPE	1
45	2202		2
46	2203		3
47	2204		4
50	2205		5
• 51	• 2206		6
• 52	• 1204		7
• 53	• 1205		8
54	1202		9
55	1203		10
56	1206		11
57	1205		12
60	0000		13
61	0000		14
62	0000		15
63	0000		16
64	0000		17
65	0000		18
66	0000		19
77667	000000001201		20

The format of this table is identical to the FORTRAN unit table (IOU) in the FORTRAN library. It is assumed that anyone attempting to change the table will be familiar with standard FORTRAN usage of table (IOU). This table appears on a separate absolute binary card in both the STRP2 and STRPR2 near the end of the decks. Changes may be made by using installation on this card or by binary corrections inserted just before the last card of each deck. The 22 word/card standard binary format is used in each deck---columnar binary in STRP2 and row binary in STRPR2. The check-sum on the cards in both decks must be either correct or zero.

As an example, suppose it is desired to change the actual 7090 tape assignment of logical tape 3 from B3 to C1. Location 77746 would be changed from 2203 to 3201 in both the STRP2 and STRPR2 decks.

9. Recovery is initiated on STRAP procedures by loading from the on-line card reader the STRAP Recovery Deck (numbered consecutively in Columns 73-74 beginning at 01 with STRPR2 in Columns 75-80 of each card).
10. Whenever it appears that a problem on a STRAP procedure is unable to reach completion, or whenever it is desired for any reason to terminate the problem (not the job), then the following steps should be taken:
  - a. Place the computer in manual and wait until operation stops.
  - b. Place the machine in automatic.
  - c. Depress sense switch 1.
  - d. Load the STRAP Recovery Deck from the on-line card reader.
11. If it becomes necessary to interrupt a job being run, the operator should depress sense switch 1. Within 10 minutes of this step, the procedure should indicate by an on-line comment what action has been taken, and what steps must be taken to restart the procedure. In many procedures, the takedown action will consist of nothing more than skipping the problems not yet completed. If the latter alternative is taken, then the problems not processed should merely be rescheduled at a later time.

The following restrictions apply to the running of procedures S06 and S14 by the method outlined in this section:

1. Subroutine DATE (in the STRAP Control Deck) assumes that the current date is stored in cell (142)<sub>8</sub> in standard FORTRAN format. If local changes to the FORTRAN system have altered this standard, then subroutine DATE should be replaced by a subroutine which does the following:
  - a. Stores the current date in absolute cell (77777)<sub>8</sub> as an integer of the form:  
$$(\text{MONTH}) \cdot 10000 + (\text{DAY OF MONTH}) \cdot 100 + (\text{LAST TWO DIGITS OF YEAR}).$$
  - b. Returns control to 1,4.

Subroutine DATE is on standard relocatable binary instruction cards near the beginning of the STRAP Control Deck.

2. Whenever a recovery or termination of a problem is executed, the following items should be noted:
  - a. The correct date may not appear on the remaining output of the job on which recovery was made.
  - b. Information retained between jobs in locations (3)8 - (143)8 will probably be lost.
  - c. When the job is complete, an on-line comment will be given directing the operator to reload the START card to begin the next job on the input tape.

Both procedures, S06 and S14, will give error prints in the event that one of the following situations exists:

1. The wrong source library has been loaded. This will cause the machine to stop after printing WRONG LIBRARY.
2. A calculated value of R or ALPHA does not fall within the range of input values of R1 or ALPHAL. This will cause the machine to go to the next problem after printing A VALUE OF R1 OR ALPHAL CALLS FOR EXTRAPOLATION; the values of K, L, I, J, X, Y, R, ALPHA involved; and the maximum and minimum values of R1 and ALPHAL. K, L, I, and J are subscripts on sub-area, energy, mesh point in X mesh, and mesh point in Y mesh, respectively.

When the cross-section libraries loaded in procedure S06 do not agree with those called for in the problem deck, the following print out will be given: LIBRARIES LOADED DO NOT AGREE WITH THOSE REQUESTED.

## REFERENCES

1. Beale, R. H., et al., Test Bed Configurations for the Flight Testing of SNAP-8 Powered Electric Propulsion Systems. Jet Propulsion Laboratory Technical Report 32-190 (November 1961).
2. Stephenson, R., Introduction to Nuclear Engineering. New York: McGraw-Hill Book Company (1954).
3. Peterson, D. M., Shield Penetration Programs C-17 and L-63. GD/FW Report FZK-9-170 (NARF-61-39T, December 1961).
4. Clark, F. H., Wogulis, S. G., and Davis, M. W., Physics Measurements of the SNAP Experimental Reactor. Atomic International Report NAA-SR-5619 (January 1961).
5. Diekamp, H. M., Bolent, R., and Welch, J. R., "Compact Reactors for Space Power." Nucleonics 19 (April 1961), 73.
6. Troubetzkoy, E. S., Fast-Neutron Cross Sections of Iron, Silicon, Aluminum, and Oxygen. Nuclear Development Corporation of America Report NDA 2111-3, Volume C (November 1959).
7. Rockwell, T., Reactor Shielding Design Manual. Atomic Energy Commission Report TID-7001 (March 1958).
8. Collins, D. G., A Monte Carlo Procedure for Calculating Penetration of Neutrons Through Straight Cylindrical Ducts. GD/FW Report MR-N-286 (NARF-61-33T, November 1961).
9. Aronson, R., et al., Effect of Shield Splitting and Placement in Nuclear Propelled Space Vehicles. Technical Research Group Report TRG-136-FR (March 1961).
10. Loechler, J. J., and McDonald, J. E., Flexible Monte Carlo Programs FCM-N and FMC-G, General Electric Flight Propulsion Laboratory Report APEX-702 (April 1961).

DISTRIBUTION

FZK-154      29 October 1962

<u>Addressee</u>	<u>No. of Copies</u>
H. E. Stern (M-RP-N) Marshall Space Flight Center Huntsville, Alabama	50